

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application seeks to amend Section 4.9 of Appendix A to the Operating License. The proposed changes are being submitted to allow steam generator tubes to have a plugging limit of 63% degradation due to pitting between the tubesheet and the second support plate of the cold leg side of all four steam generators, for Cycle 4 only.

The proposed changes to the Technical Specifications are presented in Attachment I to this application. The Safety Evaluation corresponding to this change is included in Attachment II.

POWER AUTHORITY OF THE STATE
OF NEW YORK

8501250357 850117
PDR ADOCK 05000286
P PDR

By George M. Wilweeding
for Corbin A. McNeill, Jr.
Senior Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and sworn to before
me this 17 day of JANUARY 1985

[Signature]
Notary Public

MITCHELL J. WEINSTEIN
Notary Public, State of New York
No. 30-4740329
Qualified in ~~Nassau County~~ NEW YORK COUNTY
Commission Expires March 30, 1985