

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application seeks to amend Section 3.10 of Appendix A to the Operating License. The proposed changes are being submitted as a result of the Commission's rescission of the February 11, 1980 Confirmatory Order. The rescission of the 2000°F limit on fuel peak clad temperature under large break LOCA conditions allows for an increase in total core peaking factor, F_Q , from 2.13 to 2.20.

The proposed changes to the Technical Specifications are presented in Attachment I to this application. The Safety Evaluation corresponding to this change is included in Attachment II.

POWER AUTHORITY OF THE STATE
OF NEW YORK

By John C. Brons
John C. Brons
Senior Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and sworn to before me
this 18 day of April 1986

Barbara Ann McGuire

BARBARA ANN MCGUIRE
Notary Public, State of New York
No. 4851437
Qualified in Putnam County
Commission Expires Jan. 27, 19.....

8604250150 860418
PDR ADOCK 05000284
P PDR