

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application seeks to amend Section 3.8 of Appendix A to the Operating License. The proposed change will permit the discharge of more than one region of fuel (72 assemblies) from the reactor after 162 hours have elapsed since shutdown.

The proposed changes to the Technical Specifications are presented in Attachment I to this application. The Safety Evaluation corresponding to this change is included in Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK

By John C. Brons
John C. Brons
Senior Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and sworn to before me
this 14th day of January 1987

Mina Holden

MINA HOLDEN
Notary Public, State of New York
No. 453150
Qualified in Westchester County
Commission Expires March 30, 1987

8701270334 870114
PDR ADOCK 05000286
P PDR