

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application seeks to amend Sections 3.6.C and 4.1 of the Indian Point 3 Technical Specifications to include a provision for a containment ambient temperature of 130°F. This submittal supercedes the Authority's letter of September 18, 1985 which responded to a July 7, 1980 NRC letter. This July 7, 1980 letter required amending various sections of the Technical Specifications to be consistent, where appropriate and where possible, with portions of the Westinghouse Standard Technical Specifications (W-STS).

The proposed changes to the Technical Specifications are presented in Attachment I to this application. The Safety Evaluation corresponding to this change is included in Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK

By John C. Brons
John C. Brons
Senior Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and sworn to before me
this 6th day of March 1987

Barbara Ann McGuire

BARBARA ANN MCGUIRE
Notary Public, State of New York
No. 4851437
Qualified in Putnam County
Commission Expires Jan. 27, 1988

8703120372 870306
PDR ADOCK 05000286
P PDR

ATTACHMENT I TO IPN-87-013
PROPOSED TECHNICAL SPECIFICATION CHANGES
RELATED TO CONTAINMENT TEMPERATURE

NEW YORK POWER AUTHORITY
INDIAN POINT 3 NUCLEAR POWER PLANT
DOCKET NO. 50-286
DPR-64