



May 7, 1987  
IPN-87-024

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Subject: Indian Point 3 Nuclear Power Plant  
Docket No. 50-286  
Proposed Changes to the Technical Specifications  
Related to the Fuel Storage Building  
Emergency Ventilation System

Dear Sir:

This application seeks to amend Appendix A, Sections 3.8 and 4.5 of the Operating License to clarify the operation of the Fuel Storage Building Emergency Ventilation System. In order to enhance isolation of the Fuel Storage Building Emergency Ventilation System during fuel handling operations, the Authority is removing the upper and lower bypass dampers and replacing them with manual isolation devices.

Enclosed for filing is the signed original of a document entitled, "Application for Amendment to Operating License," together with Attachment I and II thereto, comprising a statement of the proposed changes to the Technical Specifications and the associated Safety Evaluation.

In accordance with 10 CFR 170.12, a check in the amount of \$150.00 is enclosed as payment of the application fee for the review of these proposed changes to the Technical Specifications.


In accordance with 10 CFR 50.91, a copy of this application and the associated attachments is being submitted to the designated New York State Official.

8705150290 870507  
PDR ADDCK 05000286  
P PDR

*Handwritten:*  
Aool w/check  
\$150  
# 285712

Should you or your staff have any questions regarding this matter, please contact Mr. P. Kokolakis of my staff.

Very truly yours,

  
John C. Brons  
Executive Vice President  
Nuclear Generation

cc: Resident Inspector's Office  
Indian Point Unit 3  
U.S. Nuclear Regulatory Commission  
P.O. Box 215  
Buchanan, NY 10511

Jay D. Dunkleberger, Director  
Technology Development Programs  
New York State Energy Office  
Two Rockefeller Plaza  
Albany, NY 12223

Mr. J. D. Neighbors, Sr. Proj. Mgr.  
Project Directorate I-1  
Division of Reactors Projects - I/II  
U.S. Nuclear Regulatory Commission  
7920 Norfolk Avenue  
Bethesda, MD 20014

U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406