

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application seeks to amend Sections 3.8, and 4.5 of the Indian Point 3 Technical Specifications to clarify the operation of the Fuel Storage Building Emergency Ventilation System. In order to enhance isolation of the Fuel Storage Building Emergency Ventilation System during fuel handling operations, the Authority is removing the upper and lower bypass dampers and replacing them with manual isolation devices.

The proposed changes to the Technical Specifications are presented in Attachment I to this application. The Safety Evaluation corresponding to this change is included in Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK

By John C. Brons
John C. Brons
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and sworn to before me
this 7 day of May 1987

Barbara Ann McGuire

BARBARA ANN MCGUIRE
Notary Public, State of New York
No. 4851437
Qualified in Putnam County 88
Commission Expires Jan. 27, 19.....

8705150298 870507
PDR ADOCK 05000286
P PDR