

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application seeks to amend Section 3.1.A of Appendix A to the Operating License. The proposed change will revise the Technical Specifications to conform with the supporting FSAR transient analyses concerning the number of reactor coolant pumps assumed to be operating when the reactor coolant system average temperature is above 350°F but below the no-load reactor coolant average temperature (hot-zero power).

The proposed changes to the Technical Specifications are presented in Attachment I to this application. The Safety Evaluation corresponding to this change is included in Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK

By John C. Brons
John C. Brons
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and sworn to before me
this 24 day of February 1988

Barbara Ann Taggart

BARBARA ANN TAGGART
NOTARY PUBLIC, State of New York
No. 4851437
Qualified in Putnam County
Commission Expires Jan. 27, 1990

8803020235 880224
PDR ADOCK 05000286
P PDR