



John C. Brons
Executive Vice President
Nuclear Generation

March 15, 1988
IPN-88-007

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
Proposed Technical Specifications Regarding
Main Steam Line Safety Valves

Dear Sir:

This application seeks to revise Appendix A, Section 3.4 of the Operating License. The proposed change would allow plant operation with one or more inoperable main steam line safety valves provided that the power range high neutron flux setpoint is reduced to a specified value.

Enclosed for filing is the signed original of a document entitled, "Application for Amendment to Operating License," together with one copy of Attachment I and II thereto, comprising a statement of the proposed changes to the Technical Specifications and the associated Safety Evaluation.

In accordance with 10 CFR 170.12, a check in the amount of \$150.00 is enclosed as payment of the application fee for the review of these proposed changes to the Technical Specifications.

In accordance with 10 CFR 50.91, a copy of this application and the associated attachments is being submitted to the designated New York State Official.

Should you or your staff have any questions regarding this matter, please contact Mr. P. Kokolakis of my staff.

Very truly yours,

A handwritten signature of John C. Brons in dark ink, written over a typed name and title.

John C. Brons
Executive Vice President
Nuclear Generation

cc: See next page

A001
w/ check \$150
#333759

8803230294 880315
PDR ADOCK 05000286
P

cc: Resident Inspector's Office
Indian Point Unit 3
U.S. Nuclear Regulatory Commission
P.O. Box 337
Buchanan, NY 10511

Jay D. Dunkleberger, Director
Technology Development Programs
New York State Energy Office
Two Rockefeller Plaza
Albany, NY 12223

Joseph D. Neighbors, Sr. Proj. Mgr.
PWR Project Directorate I-1
Division of Reactor Projects - I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14B2
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406