

John C. Brons
Executive Vice President
Nuclear Generation

April 26, 1988 IPN-88-015

U.S. Nuclear Regulatory Commission

ATTN: Document Control Desk

Washington, D.C. 20555

Subject:

Indian Point 3 Nuclear Power Plant

Docket No. 50-286

Proposed Technical Specifications Regarding Movable Incore Neutron Detector Guide Thimbles

Dear Sir:

This application seeks to revise Appendix A, Sections 3.10 and 3.11 of the Operating License. The proposed change will revise the minimum number of operable movable incore neutron detector guide thimbles required for the incore/excore detector calibration. This application also seeks to establish a limit for the minimum number of operable thimbles required for the generation of the monthly full core flux map.

Enclosed for filing is the signed original of a document entitled, "Application for Amendment to Operating License," together with one copy of Attachment I and II thereto, comprising a statement of the proposed changes to the Technical Specifications and the associated Safety Evaluation.

In accordance with 10 CFR 170.12, a check in the amount of \$150.00 is enclosed as payment of the application fee for the review of these proposed changes to the Technical Specifications.

In accordance with 10 CFR 50.91, a copy of this application and the associated attachments is being submitted to the designated New York State Official.

Should you or your staff have any questions regarding this matter, please contact Mr. P. Kokolakis of my staff.

Very truly yours,

ohn C. Brons

Executive Vice President

Nuclear Generation

cc: See next page

Apol Rec'd Clark

8805030289 880426 PDR ADOCK 05000286 cc: Resident Inspector's Office
 Indian Point Unit 3
 U.S. Nuclear Regulatory Commission
 P.O. Box 337
 Buchanan, NY 10511

Jay D. Dunkleberger, Director Technology Development Programs New York State Energy Office Two Rockefeller Plaza Albany, NY 12223

Joseph D. Neighbors, Sr. Proj. Mgr. PWR Project Directorate I-1 Division of Reactor Projects - I/II U.S. Nuclear Regulatory Commission Mail Stop 142B Washington, D.C. 20555

U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406