

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application seeks to amend Sections 3.10 and 3.11 of Appendix A to the Operating License. The proposed change will revise the minimum number of operable movable incore neutron detector guide thimbles required for the incore/excore neutron detector calibration. This application also seeks to establish a limit for the minimum number of operable thimbles required for the generation of the monthly full core flux map.

The proposed changes to the Technical Specifications are presented in Attachment I to this application. The Safety Evaluation corresponding to this change is included in Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK

By John C. Brons
John C. Brons
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and sworn to before me
this 26th day of April 1988

Mina Holden

MINA HOLDEN
NOTARY PUBLIC, State of New York
Westchester County
No. 4829150
My Commission Expires Aug. 31, 1989

8805030296 880426
PDR ADOCK 05000286
P DCD