



**John C. Brons**  
Executive Vice President  
Nuclear Generation

December 30, 1988  
IPN-88-057

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

Subject: Indian Point 3 Nuclear Power Plant  
Docket No. 50-286  
Proposed Changes to the Technical Specifications  
Weld Channel and Penetration Pressurization System  
and Isolation Valve Seal Water System

Dear Sir:

This application seeks to revise Appendix A, Section 3.3 and Section 4.4 of the Indian Point 3 Operating License. The proposed change will revise the Limiting Condition for Operation (LCO) for the Isolation Valve Seal Water System (IVSWS) and the Weld Channel and Penetration Pressurization System (WC&PPS) to more closely reflect the system design and the appropriate Westinghouse Standard Technical Specification provisions. The allowable outage time will be extended from four days to seven days to restore operability to those system portions identified by the Technical Specifications. The proposed LCO will be clarified to specifically apply to the four independent WC&PPS zones and the station headers of the IVSWS which supply seal water directly to containment isolation valves. In addition, this proposed change will relocate an LCO for the WC&PPS located in Section 4.4, Surveillance Requirements, to Section 3.3.

Enclosed for filing is the signed original document entitled, "Application for Amendment to Operating License," together with Attachment I and II thereto, comprising a statement of the proposed changes to the Technical Specifications and the associated Safety Evaluation.

In accordance with 10 CFR 170.12, a check in the amount of \$150.00 is enclosed as payment of the application fee for the review of these proposed changes to the Technical Specifications.


In accordance with 10 CFR 50.91, a copy of this application and the associated attachments is being submitted to the designated New York State Official.

8901110026 881230  
PDR ADDCK 05000286  
P PNU

A001  
w/ check \$150  
#373017

Should you or your staff have any questions regarding this matter, please contact Mr. P. Kokolakis of my staff.

Very truly yours,

  
John C. Brons  
Executive Vice President  
Nuclear Generation

cc: U.S. Nuclear Regulatory Commission  
475 Allendale Rd.  
King of Prussia, PA 19406

Resident Inspector's Office  
Indian Point Unit 3  
U.S. Nuclear Regulatory Commission  
P.O. Box 337  
Buchanan, N.Y. 10511

Ms. Donna Ross  
New York State Energy Office  
2 Empire State Plaza 16th Floor  
Albany, N.Y. 12223

Joseph D. Neighbors, Sr. Proj. Manager  
Project Directorate I-1  
Division of Reactor Projects I/II  
U.S. Nuclear Regulatory Commission  
Mail Stop 14B2  
Washington, D.C. 20555

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the matter of )  
POWER AUTHORITY OF THE STATE OF NEW YORK ) Docket No. 50-286  
Indian Point 3 Nuclear Power Plant )

APPLICATION FOR AMENDMENT TO  
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application seeks to revise Sections 3.3 and 4.4 of Appendix A to the Operating License. The proposed change will revise the Limiting Condition for Operation (LCO) for the the Isolation Valve Seal Water System (IVSWS) and Weld Channel and Penetration Pressurization System (WC&PPS) to more closely reflect system design and the appropriate provisions of Westinghouse Standard Technical Specifications. In addition, an LCO for the WC&PPS will be relocated from the Surveillance Requirements, Section 4.4. to the LCO, Section 3.3.

The proposed changes to the Technical Specifications are presented in Attachment I to this application. The Safety Evaluation corresponding to this change is include in Attachment II.

POWER AUTHORITY OF THE  
STATE OF NEW YORK

By John C. Brons  
John C. Brons  
Executive Vice President  
Nuclear Generation

STATE OF NEW YORK  
COUNTY OF WESTCHESTER

Subscribed and sworn to before me  
this 30<sup>th</sup> day of December 1988

Mina Holden

**MINA HOLDEN**  
NOTARY PUBLIC, State of New York  
Westchester County  
No. 4829150  
My Commission Expires Aug. 31, 1989