

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
POWER AUTHORITY OF THE STATE OF NEW YORK ) Docket No. 50-286  
Indian Point 3 Nuclear Power Plant )


APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application seeks to amend pages 3.5-8, 4.1-3, 4.1-4 ( a new page ), Table 4.1-1 (Sheet 1 of 5), Table 4.1-1 (Sheet 2 of 5), Table 4.1-1 (Sheet 3 of 5), and Table 4.1-1 (Sheet 5 of 5) to extend the surveillance intervals of the Reactor Protection System and Engineered Safety Features analog channels from monthly to quarterly, and to allow routine analog channel testing in bypass, in the Indian Point 3 Technical Specifications. This application also seeks to correct a typographical error introduced through a previous amendment request.


The proposed changes to the Technical Specifications are presented in Attachment I to this application. The Safety Evaluation is included in Attachment II.

POWER AUTHORITY OF THE  
STATE OF NEW YORK

  
By \_\_\_\_\_  
John C. Brons  
Executive Vice President  
Nuclear Generation

STATE OF NEW YORK  
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me  
this 20th day of December 1989

  
\_\_\_\_\_  
Notary Public

**MINA HOLDEN**  
NOTARY PUBLIC, State of New York  
Westchester County  
No. 4829150  
My Commission Expires Aug. 31, 1993

8912280201 891220  
PDR ADOCK 05000286  
P FDC