

White, John

From: John White
Sent: Friday, May 15, 2009 8:13 AM
To: Neil Sheehan
Cc: Ronald Nimitz; Harold Gray; John Richmond
Subject: RE: Question re: Oyster Creek inspections

A 6" aluminum pipe (A-4, condensate pumps to turbine building) in the same area was inspected previously. The leaking pipes were CS-24 (10" carbon steel associated with hotwell level control) and CS-25 (8" carbon steel associated with hotwell level control). They were not selected for prior inspection.

From: Neil Sheehan
Sent: Thursday, May 14, 2009 4:06 PM
To: John White
Subject: Question re: Oyster Creek inspections

Can you refresh my memory on this?

Neil:

(b)(5)

7
5

Thanks.

Todd

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 5
FOIA- B-007-0214