

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)

POWER AUTHORITY OF THE STATE OF NEW YORK)

) Docket No. 50-286

Indian Point 3 Nuclear Power Plant)


APPLICATION FOR AMENDMENT TO OPERATING LICENSE


Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

These proposed Technical Specification changes to Table 3.6-1 and Table 4.4-1 (page 5 of 7) reflect the removal of Containment Isolation Valves UH-37 and UH-38. The changes will eliminate the need for maintaining and testing valves UH-37 and UH-38.

The proposed changes to the Technical Specifications are presented in Attachment I to this application. The Safety Evaluation is included in Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK



By  John C. Brons
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me
this 19th day of September 1990



Notary Public

BARBARA ANN TAGGART
NOTARY PUBLIC, State of New York
No. 4851437
Qualified in Putnam County
Commission Expires Jan. 27, 19 92

9010010091 900919
PDR ADOCK 05000286
P PDC