ATTACHMENT I TO IPN-90-049

PROPOSED TECHNICAL SPECIFICATION CHANGES

RELATED TO

THE REMOVAL OF CONTAINMENT ISOLATION VALVES UH-37 AND UH-38

NEW YORK POWER AUTHORITY INDIAN POINT 3 NUCLEAR POWER PLANT DOCKET NO. 50-286 DPR-64

9010010096 900919 PDR ADOCK 05000286 PDC PDC

		·			
	TABLE 3.6-1				
NON-AUTOM	ATTC CONTAINMENT ISOLAT	TON VALVES			
OPEN CONTINUOUSLY OR INTERMITTENTLY FOR PLANT OPERATION					
VALVE NO.	VALVE NO.	VALVE NO.			
OPEN CONTINUOUS VALVE NO. AC-MOV-744 AC-MOV-743 SP-990C AC-732 SI-MOV-885A SI-MOV-885B CH-MOV-205 CH-MOV-205 CH-MOV-205 CH-MOV-250A CH-MOV-250B CH-MOV-441 CH-MOV-250B CH-MOV-443 CH-MOV-250D CH-MOV-443 CH-MOV-444 SI-869A SI-869B SI-878A SI-878B SI-MOV-851A SI-MOV-850A	LY OR INTERMITTENTLY FO VALVE NO. SI-MOV-850C SI-1833A SI-1833B SI-859A SI-859C AC-752F AC-753F AC-753J SWN-41-1 SWN-43-1 SWN-43-2 SWN-41-2 SWN-43-2 SWN-41-3 SWN-41-3 SWN-41-4 SWN-43-4 SWN-43-5 SWN-44-1 SWN-44-1 SWN-51-1 SWN-51-2 SWN-44-3 SWN-51-3 SWN-44-4	R PLANT OPERATION VALVE NO. SWN-51-4 SWN-44-5 SWN-71-5 SWN-71-1 SWN-71-2 SWN-71-3 SWN-71-4 SWN-71-5 SA-24-1 SA-24-2 PS-PCV-1111-1 PS-PCV-1111-1 PS-PCV-1111-2 SP-MOV-990A SP-MOV-990B SI-1814A SI-1814B SI-1814A SI-1814A SI-1814A SI-1814B SI-1814A SI-1814B SI-1814A SI-1814B SI-1814B SI-1814C HR-MOV-1875A HR-MOV-1875B HR-MOV-1876A HR-MOV-1876B PS-7 PS-8 PS-9 PS-10			
	•				
	· · ·				

Amendment No. 56, 192,

CONTAINMENT ISOLATION VALVES				
	Penetration		Minimum Test	
<u>Valve No.</u>	Number ⁽¹⁾	Test Fluid ⁽²⁾	Pressure (PSIG) (8	
SWN-44-5	40	Water ⁽⁶⁾	47	
SWN-51-5	40	Water ⁽⁶⁾	47	
SWN-71-1	40	Water ⁽⁶⁾	47	
SWN-71-2	40	Water ⁽⁶⁾	47	
SWN-71-3	40	Water ⁽⁶⁾	47	
SWN-71-4	40	Water ⁽⁶⁾	47	
SWN-71-5	40	Water ⁽⁶⁾	47	
SA-24-1	41	Water ⁽⁴⁾	47	
SA-24-2	41	Water ⁽⁴⁾	47	
VS-FCV-1170	48	G _{as} (7)	43	
VS-FCV-1171	48	$Gas^{(7)}$	43	
VS-FCV-1172	49	Gas ⁽⁷⁾	43	
VS-FCV-1173	49	Gas ⁽⁷⁾	43	
VS-FCV-1190	50	$Gas^{(7)}$	43	
VS-FCV-1191	50	_{Gas} (7)	43	
VS-FCV-1192	50	Gas ⁽⁷⁾	43	
SP-MOV-990A	51	Nitrogen ⁽⁴⁾	43	
SP-MOV-990B	51	Nitrogen ⁽⁴⁾	43	
SP-AOV-956A	52	Water ⁽⁴⁾	47	
SP-AOV-956B	52	Water ⁽⁴⁾	47	
SP-AOV-956C	53	Water ⁽⁴⁾	47	
SP-AOV-956D	53	Water ⁽⁴⁾	47	
SI-1814A	54	Gas	43	
SI-1814B	55	Gas	43	
SI-1814C	56	Gas	43	
SP-SOV-506	57	Gas	43	
SP-SOV-507	57	Gas	43	

TABLE 4.4-1 (Page 5 of 7)

4

ļ

•

ATTACHMENT II TO IPN-90-049

SAFETY EVALUATION OF PROPOSED TECHNICAL SPECIFICATION CHANGES ASSOCIATED WITH THE REMOVAL OF CONTAINMENT ISOLATION VALVES UH-37 AND UH-38

NEW YORK POWER AUTHORITY INDIAN POINT 3 NUCLEAR POWER PLANT DOCKET NO. 50-286 DPR-64



SAFETY EVALUATION OF PROPOSED TECHNICAL SPECIFICATION CHANGES ASSOCIATED WITH THE REMOVAL OF CONTAINMENT ISOLATION VALVES UH-37 AND UH-38

Section I - Description of Changes

The proposed changes to Table 3.6-1 and Table 4.4-1 (Page 5 of 7) of the Technical Specifications reflect the removal of Containment Isolation Valves UH-37 and UH-38. Removal of these valves will eliminate the need for maintaining and testing valves UH-37 and UH-38.

Section II - Evaluation of Changes

Containment Isolation Valves UH-37 and UH-38 are on the Auxiliary Steam Supply and Condensate Return (ASC) System steam supply and condensate return lines, respectively. These lines originally were designed to supply steam to the Containment Unit Heaters. Since the temperature in containment is maintained without the use of the Unit Heaters, auxiliary steam is no longer required to be supplied to containment. Since valves UH-37 and UH-38 are containment isolation valves, they are required per the Technical Specifications to be maintained and tested.

A plant modification proposes to remove UH-37 and UH-38, and to cut and cap the adjacent piping near both sides of their respective containment penetrations. This modification would enhance the integrity of the containment penetrations by assuring that the capped piping sections through the penetrations are leak tight.

The Technical Specification Changes transmitted by this submittal reflect the changes associated with the plant modification described above. The changes will eliminate the need for maintaining and testing valves UH-37 and UH-38.

Section III - No Significant Hazards Evaluation

Consistent with the requirements of 10 CFR 50.92, the enclosed application is judged to involve no significant hazards based on the following information:

(1) Does the proposed license amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response:

The proposed changes reflect a plant modification that will enhance the integrity of the containment penetrations associated with the ASC steam supply and condensate return lines. The modification will cap the two lengths of piping penetrating containment. The capped piping will be leak tight,



therefore the technical specification changes associated with this modification do not involve a significant increase in the probability or consequences of an accident previously evaluated.

(2) Does the proposed license amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response:

The proposed changes reflect a plant modification that will provide containment isolation at the containment penetrations associated with the ASC steam supply and condensate return lines. Since this is the same function currently provided by containment isolation valves UH-37 and UH-38, the removal of these valves and associated technical specification changes do not create the possibility of a new or different kind of accident from any accident previously evaluated.

(3) Does the proposed amendment involve a significant reduction in a margin of safety?

Response:

The proposed amendment does not involve a significant reduction in a margin of safety since it reflects a plant modification that will enhance containment integrity by providing leak tight seals at the penetrations associated with the ASC steam supply and condensate return lines.

Section IV - Impact of Change

This change will not adversely impact the following:

ALARA Program Security and Fire Protection Programs Emergency Plan FSAR or SER Conclusions Overall Plant Operations and the Environment

Section V - Conclusions

The incorporation of this change: a) will not increase the probability nor the consequences of an accident or malfunction of equipment important to safety as previously evaluated in the Safety Analysis Report; b) will not increase the possibility for an accident or malfunction of a different type than any evaluated previously in the Safety Analysis Report; c) will not reduce the margin of safety as defined in the bases for any Technical Specification; d) does not constitute an unreviewed safety question; and e) involves no significant hazards considerations as defined in 10 CFR 50.92.



Attachment II IPN-90-049 Page 3 of 3

Section VI - References

•

a)	IP-3 FSAR
b)	IP-3 SER