



John C. Brons
Executive Vice President
Nuclear Generation

December 11, 1990
IPN-90-055

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

Attn: Document Control Desk

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
Administrative Correction to the Technical Specifications

Reference: 1. NYPA letter, J.C. Brons to the NRC, "Proposed Technical Specification Changes to Increase the Design Basis Ultimate Heat Sink Temperature," dated July 24, 1989.


Dear Sir:

The current Indian Point 3 Technical Specifications contain an administrative error that was introduced by a proposed Technical Specification change. A correct version of the page that contains the error, page 4.4-1, is attached. Please reissue this corrected page 4.4-1.

By letter dated July 24, 1989 (Reference 1), the Authority proposed changing the Indian Point 3 ultimate heat sink design basis temperature to 95°F. In providing the Technical Specification pages that would be affected, a portion of the Technical Specifications that was changed by amendment 77 (issued July 13, 1987) was inadvertently deleted. The option of performing Integrated Leakage Rate Testing as described in report BN-TOP-1 was deleted from Specification 4.4.A.1.b. The correct wording of Specification 4.4.A.1.b is included in the attached page 4.4-1.

If you have any questions, please contact Mr. P. Kokolakis of my staff.

Very truly yours,


John C. Brons
Executive Vice President
Nuclear Generation

cc: See next page

9012190038 901211
PDR ADOCK 05000286
PDR

A001

Attachment

cc: U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector's Office
Indian Point 3
U.S. Nuclear Regulatory Commission
P.O. Box 337
Buchanan, NY 10511

Mr. J. D. Neighbors, Sr. Project Manager
Project Directorate I-1
Division of Reactor Projects-I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14B2
Washington, D.C. 20555