



John C. Brons
Executive Vice President
Nuclear Generation

March 28, 1991
IPN-91-010

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

Attn: Document Control Desk

Subject: **Indian Point 3 Nuclear Power Plant**
Docket No. 50-286
Proposed Changes to Technical Specifications
Regarding the Fire Protection and Detection Systems

Dear Sir:

This application for amendment to the Indian Point 3 Technical Specifications requests that smoke detectors and hose stations located in the intake structure building be added to the lists of equipment (Tables 3.14-1 and 3.14-2) that are required to be operable. These smoke detectors and hose stations are being added to a new building that is being erected to enclose the intake structure. The purpose of the intake structure enclosure is to provide weather protection for performing maintenance on the Service Water Pumps, the Circulating Water Pumps, and the Travelling Screens.

This application also seeks to make miscellaneous corrections to specification 3.14.C.2., Table 3.14-1, and re-paginate all section 3.14 pages except 3.14-1.

Enclosed for filing is the signed original of a document entitled, "Application for Amendment to Operating License," together with Attachments I and II, comprising a statement of the proposed changes to the Technical Specifications and the associated Safety Evaluation.


In accordance with 10 CFR 50.91, a copy of this application and the associated attachments are being submitted to the designated New York State official.

9104020004 910328
PDR ADOCK 05000286
P PDR

A001
111

If you have any questions, please contact Mr. P. Kokolakis.

Very truly yours,


John C. Brons
Executive Vice President
Nuclear Generation

Attachments

cc: U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector's Office
Indian Point Unit 3
U.S. Nuclear Regulatory Commission
P.O. Box 337
Buchanan, NY 10511

Ms. Donna Ross
Division of Policy Analysis & Planning
Empire State Plaza
Building Number 2 - 16th Floor
Albany, NY 12223

Joseph D. Neighbors, Sr. Proj. Manager
Project Directorate I-1
Division of Reactor Projects I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14B2
Washington, D.C. 20555