

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application for amendment to the Indian Point 3 Technical Specifications seeks to revise Section 3.1.A (Operational Components), Section 3.1.B (Heatup and Cooldown), Section 3.3 (Engineered Safety Features) and Section 4.3 (Reactor Coolant System Integrity Testing). These sections are being amended to extend the Heatup-Cooldown limits to 11.0 effective full power years (EFPYs) and to provide for the corresponding Overpressure Protection System (OPS) limits.

In addition to the technical changes, the affected sections are being amended to implement pagination and format changes that constitute human factors improvements to these sections and to correct typographical errors.

The proposed changes to the Technical Specifications are Attachment I to this application. The Safety Evaluation is included in Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK



By
Ralph E. Beedle
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me
this 28 day of October 1991

Barbara Ann Taggart
Notary Public

BARBARA ANN TAGGART
NOTARY PUBLIC, State of New York
No. 4851437
Qualified in Putnam County 92
Commission Expires Jan. 27, 19

9111070129 911028
PDR ADOCK 05000286
P FDR