

BEFORE THE UNITED STATES

NUCLEAR REGULATORY COMMISSION

In the Matter of
POWER AUTHORITY OF THE STATE OF NEW YORK
Indian Point 3 Nuclear Power Plant

)
) Docket No. 50-286
)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application for amendment to the Indian Point 3 Technical Specifications seeks to amend Section 3.3.G (Hydrogen Recombiner and Containment Hydrogen Monitoring Systems), Section 4.5.A.2 (Hydrogen Recombiner and Containment Monitoring Systems) and Table 4.4-1 (Containment Isolation Valves). The Technical Specifications are being revised to amend the Limiting Condition for Operation (LCO) and Surveillance Requirements for the hydrogen recombiners to reflect a plant modification converting from mechanical to electric recombiners.

The proposed changes to the Technical Specifications are Attachment I to this application. The Safety Evaluation is included in Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK



By
Ralph E. Beedle
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me
this 18th day of November 1991



Notary Public

MINA HOLDEN
NOTARY PUBLIC, State of New York
Westchester County
No. 4829150
My Commission Expires Aug. 31, 1993