

Indian Point 3  
Nuclear Power Plant  
P.O. Box 215  
Buchanan, New York 10511  
914 736.8001



Joseph E. Russell  
Resident Manager

June 23, 1992  
IP3-NRC-92-041

License No. 50-286  
Docket No. DPR-64

Mr. Thomas T. Martin  
Regional Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Dear Mr. Martin:

This correspondence provides information required by the Special Reports section (6.9.2) of the Indian Point Unit Three (IP3) Technical Specifications.

Technical Specification 3.14.C, "Penetration Fire Barriers", subsection 2, states that, "If the requirements of 3.14.C.1 are not met and the equipment in these areas are (sic) required to be operable:...Restore the non-functional fire barrier penetration(s) to functional status within seven days or submit a report to the Commission pursuant to specification 6.9.2.f within the next 30 days outlining the action taken, the cause of the non-functional penetration and plans for restoring the fire barrier penetration(s) to functional status."

On May 9, 1992, and May 20, 1992, cable spreading room fire barrier penetrations were opened to pull cables to support installation of a modification to replace the existing containment air particulate and gas radiation monitors (R11/12). The penetrations are from the cable spreading room to the control room and electrical tunnel area. These penetrations will remain open until cable is pulled for other radiation monitor upgrades including steam generator blowdown effluent (R19), service water system effluent (R16, R23), condenser air ejector noble gas (R15), and liquid waste effluent (R18).


9206300174 920623  
PDR ADOCK 05000286  
PDR

LEO  
1/0

A Fire Watch was established on May 9, and will be continued until cable pulling is complete and the penetration is returned to functional status. This task is expected to be completed by June 30, 1992.

Should you or your staff have any questions regarding this event, please contact Mr. B. Ray of my staff.

Sincerely,



Joseph E. Russell  
Resident Manager  
Indian Point Three Nuclear Power Plant

jer/wje/rj

cc: U.S. Nuclear Regulatory Commission (original)  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

IP3 Resident Inspector  
Indian Point 3  
U.S. Nuclear Regulatory Commission  
P.O. Box 337  
Buchanan, New York 10511