d.

The following check values shall be checked for gross leakage midway between refuelings:

838A	895A	897A
838B	895B	897B
838C	895C	897C
838D	895D	897D

<u>Basis</u>

The Safety Injection System and the Containment Spray System are principal plant safeguards that are normally on standby during reactor operation. Complete systems tests cannot be performed when the reactor is operating because a safety injection signal causes reactor trip, main feedwater isolation and containment isolation, and a Containment Spray System test requires the system to be temporarily disabled. The method of assuring operability of these systems is, therefore, to combine systems tests to be performed during plant shutdowns, with more frequent component tests, which can be performed during reactor operation.

The systems tests demonstrate proper automatic operation of the Safety Injection and Containment Spray Systems. With the pumps blocked from starting, a test signal is applied to initiate automatic action and verification made that the components receive the safety injection signal in the proper sequence. The test demonstrates the operation of the valves, pump circuit breakers, and automatic circuitry.⁽¹⁾

During reactor operation, the instrumentation which is depended on to initiate safety injection and containment spray is generally checked daily and the initiating circuits are tested monthly (in accordance with Specification 4.1). The testing of the analog channel inputs is accomplished in the same manner as for the reactor protection system. The engineered safety features logic system is tested by means of test switches to simulate inputs from the analog channels. The test switches allow actuation of the master relay, while at the same time blocking the slave relays. Verification that the logic is accomplished is indicated by the matrix test light. The

4.5-8

Amendment No.

208190071 920806