

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO THE OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an amendment to the Technical Specifications contained in Appendix A of this license.

Starting with cycle nine (that began in August, 1992), Indian Point 3 began operating on 24 month cycles, instead of the previous 18 month cycles. This application for amendment to the Indian Point 3 Technical Specifications proposes to change the frequency of Emergency Diesel Generator testing to accommodate operation with a 24 month operating cycle.

The proposed changes to the Technical Specifications are included as Attachment I to this application. The Safety Evaluation is included as Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK


By

Ralph E. Beedle
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me
this 19th day of October, 1992


Notary Public

GERALDINE STRAND
Notary Public, State of New York
No. 4991272
Qualified in Westchester County
Commission Expires Jan. 27, 1994

9210260094 921019
PDR ADOCK 05000286
P PDR