

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
POWER AUTHORITY OF THE STATE OF NEW YORK ) Docket No. 50-286  
Indian Point 3 Nuclear Power Plant )

**APPLICATION FOR AMENDMENT TO THE OPERATING LICENSE**

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an amendment to the Technical Specifications contained in Appendix A of this license.

Starting with cycle nine (that began in August 1992), Indian Point 3 began operating on 24 month cycles, instead of the previous 18 month cycles. This application for amendment to the Indian Point 3 Technical Specifications proposes to change the frequency of Hydrogen Recombiner system testing to accommodate operation with a 24 month operating cycle.

The proposed change to the Technical Specifications is included as Attachment I to this application. The Safety Evaluation is included as Attachment II.

POWER AUTHORITY OF THE  
STATE OF NEW YORK



By  
**Ralph E. Beedle**  
Executive Vice President  
Nuclear Generation

STATE OF NEW YORK  
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me  
this 19<sup>th</sup> day of January 1993

  
Notary Public

**KATHLEEN D. GALLAGHER**  
Notary Public, State of New York  
No. 5004481  
Qualified in Westchester County  
Commission Expires Nov. 18, 1994

9301270230 930119  
PDR ADOCK 05000286  
P PDR