

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
POWER AUTHORITY OF THE STATE OF NEW YORK ) Docket No. 50-286  
Indian Point 3 Nuclear Power Plant )

**APPLICATION FOR AMENDMENT TO OPERATING LICENSE**

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for amendment to the Technical Specifications contained in Appendix A and Appendix B of this license.

This application for amendment to the Indian Point 3 (IP3) Technical Specifications proposes to change calibration requirements for the Radiation Monitoring System to accommodate operation with a 24 month operating cycle. The specific technical specifications that will be changed by this application are:


- calibration frequency of process and area radiation monitors (Appendix A Table 4.1-1 and Appendix B Tables 3.1-1 and 3.2-1),
- calibration frequency of radioactivity recorders (Appendix B Table 3.1-1).

Also included are:

- a bases change to Appendix A Section 3.3 to clarify IP3 requirements associated with Central Control Room (CCR) radiation monitoring,
- administrative changes to Appendix A Table 4.1-1 to specify radiation monitors by function and tag number and to incorporate all radiation monitors that have technical specification required surveillance into one item number in the table,
- administrative changes to Appendix B Tables 3.1-1 and 3.2-1 to identify the radiation monitor tag number associated with each monitoring function listed,
- administrative changes to Appendix B Tables 2.1-1 and 3.1-1 to clarify monitoring requirements associated with the condensate polisher waste release path, and
- administrative changes to Appendix B Table 3.1-1 to clearly distinguish the surveillance requirement for R-23 as once per 18 months.

The proposed changes to the Technical Specifications are included as Attachment I to this application. The Safety Evaluation is included as Attachment II.

POWER AUTHORITY OF THE  
STATE OF NEW YORK



By  
**Ralph E. Beedle**  
Executive Vice President  
Nuclear Generation

STATE OF NEW YORK  
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me  
this 25<sup>th</sup> day of January 1993

  
Notary Public

**KATHLEEN S. GALLAGHER**  
Notary Public, State of New York  
Qualified in Westchester County  
Commission Expires Nov. 24, 1994

9302010257 930125  
PDR ADOCK 05000286  
P PDR