

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO THE OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for amendment to the Technical Specifications contained in Appendix A of this license.

The temperature sensors can be tested at power, so there is no burden for testing the Primary Auxiliary Building area temperature sensors at power. However, past test results, on-line testing, and redundant sensors provide adequate assurance that this surveillance can safely be extended. Extending the surveillance interval will decrease the overall burden of testing.

The proposed change to the Technical Specifications is included as Attachment I to this application. The Safety Evaluation is included as Attachment II.


POWER AUTHORITY OF THE
STATE OF NEW YORK



By
Ralph E. Beedle
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me
this 9th day of April 1993



Notary Public

EILEEN E. O'CONNOR
Notary Public, State of New York
No. 4991062
Qualified in Westchester County
Commission Expires January 21, 1994