

123 Main Street  
White Plains, New York 10601  
914 681.6846



**Ralph E. Beedle**  
Executive Vice President  
Nuclear Generation

April 9, 1993  
IPN-93-019

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Subject: **Indian Point 3 Nuclear Power Plant**  
**Docket No. 50-286**  
**Proposed Changes to Technical Specifications**  
**Regarding Extending Turbine Building Level Sensor**  
**Testing to Accommodate a 24 Month Operating Cycle**

Dear Sir:

This application for amendment to the Indian Point 3 Technical Specifications proposes to change the frequency of Turbine Building level sensor testing to 24 months. Starting with cycle nine (August, 1992), Indian Point 3 began operating on 24 month cycles, instead of 18 month cycles.

The level sensors can be tested at power, so there is no burden for testing the Turbine Building level sensors at power. However, past test results, on-line testing, and redundant sensors provide adequate assurance that this surveillance can safely be extended. Extending the surveillance interval will decrease the overall burden of testing.

The proposed change is contained in Attachment I to the Application for Amendment enclosed with this letter, and the associated Safety Evaluation is provided as Attachment II.


A copy of this application and the associated attachments are being provided to the designated New York State official as required by 10 CFR 50.91.

120066  
9304120256 930409  
PDR ADOCK 05000286  
P PDR

ADD 1/1

If you have any questions, please contact Mr. P. Kokolakis.

Very truly yours,



Ralph E. Beedle

Attachments: as stated

cc: U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Resident Inspector's Office  
Indian Point Unit 3  
U.S. Nuclear Regulatory Commission  
P.O. Box 337  
Buchanan, NY 10511

Ms. Donna Ross  
Division of Policy Analysis & Planning  
Empire State Plaza  
Building Number 2 - 16th Floor  
Albany, NY 12223

Mr. Nicola F. Conicella, Project Manager  
Project Directorate I-1  
Division Of Reactor Projects I/II  
U.S. Nuclear Regulatory Commission  
Mail Stop 14B2  
Washington, DC 20555