

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of
POWER AUTHORITY OF THE STATE OF NEW YORK)
Indian Point 3 Nuclear Power Plant) Docket No. 50-286


APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

These proposed Technical Specification changes eliminate the Boron Injection Tank (BIT). Westinghouse Electric Corporation has developed improved analytical techniques that show the acceptability of BIT removal for Indian Point Unit 3 while continuing to meet applicable safety criteria. References to the BIT have been deleted/revise in sections 3.2, 3.3, and 4.1. In addition, this application seeks to amend section 4.4 to remove a reference to containment temperature in the acceptance criteria for the containment leak test. The leak test specification and basis are amended to indicate the postulated peak containment temperature and pressure determined by current analysis.

The proposed changes to the Technical Specifications are Attachment I to this application. The Safety Evaluation is included in Attachment II. A Westinghouse report (WCAP-12269) has been provided previously, by letter dated July 24, 1989. Attachment III is a report entitled "Revised Feasibility Report for BIT Elimination for Indian Point Unit 3."

POWER AUTHORITY OF THE
STATE OF NEW YORK



By
Ralph E. Beedle
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me
this 4th day of May 1993


Notary Public

KATHLEEN D. GALLAGHER
Notary Public, State of New York
No. 5004481
Qualified in Westchester County
Commission Expires Nov. 16, 1994

9305110280 930504
PDR ADOCK 05000286
P PDR