

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO THE OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for amendment to the Technical Specifications contained in Appendix A and Appendix B of this license.


This application for amendment to the Indian Point 3 Technical Specifications proposes to change the frequency of chemical and volume control system testing to accommodate operation with a 24 month operating cycle.

Starting with cycle nine (August, 1992), Indian Point 3 began operating on 24 month cycles, instead of the current 18 month cycles. The specific Technical Specifications that will be changed by this application are:

- Boric Acid Tank level calibration.
- Boric Acid Makeup Flow Channel calibration.
- City Water connections to charging pumps and boric acid piping.
- Primary Water Storage Tank channel calibration and functional test.

The proposed changes to the Technical Specifications are included as Attachment I to this application. The Safety Evaluation is included as Attachment II.

POWER AUTHORITY OF THE
STATE OF NEW YORK



By
Ralph E. Beedle
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me
this 18th day of May 1993


Notary Public

KATHLEEN D. GALLAGHER
Notary Public, State of New York
No. 5004481
Qualified in Westchester County
Commission Expires Nov. 10, 1994

9305250200 930518
PDR ADOCK 05000286
P PDR