

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO THE OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an amendment to the Technical Specifications contained in Appendix A of this license.


Starting with cycle nine (that began in August 1992), Indian Point 3 began operating on 24 month cycles; instead of the previous 18 month cycles. This application for amendment to the Indian Point 3 Technical Specifications proposes to change the frequency of Engineered Safety Features systems testing to accommodate operation with a 24 month operating cycle. The proposed changes extend the frequency for performing:

- the safety injection system test (Specification 4.5.A.1.a),
- the loss of normal AC power/safety injection test (Specification 4.6.A.3; this specification is also being reformatted), and
- the auxiliary feedwater system undervoltage and main feedwater pump trip tests (Table 4.1-1, items 28.b and c).

Also included is the addition, to Table 4.1-1, of surveillance requirements for steam line flow instrumentation.

The proposed changes to the Technical Specifications are included as Attachment I to this application. The Safety Evaluation is included as Attachment II.


POWER AUTHORITY OF THE
STATE OF NEW YORK



By
Ralph E. Beedle
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and Sworn to before me
this 21st day of May 1993


Notary Public

KATHLEEN D. GALLAGHER
Notary Public, State of New York
No. 5004481
Qualified in Westchester County
Commission Expires Nov. 16, 1994

9306010165 930521
PDR ADDCK 05000286
P PDR