

**REQUEST FOR ADDITIONAL INFORMATION 499-4060 REVISION 0**

12/1/2009

US-APWR Design Certification

Mitsubishi Heavy Industries

Docket No. 52-021

SRP Section: 14.03.03 - Piping Systems and Components - Inspections, Tests, Analyses, and  
Acceptance Criteria

Application Section: Tier 1, Tier 2 Section 14.3.3

QUESTIONS for Engineering Mechanics Branch 2 (ESBWR/ABWR Projects) (EMB2)

14.03.03-23

In the response to RAI 404-3063, Question 14.03.03-18, MHI proposed ITAAC to have the following available: (a) design reports of representative Class 2 and 3 PSC, (b) design specifications of all Class 2 and 3 PSC, and (c) design reports of risk significant Class 2 and 3 PSC

In Question 14.03.03-18 the staff indicated, that the ITAAC should be for all Class 2 and 3 PSC.

Provide modified ITAAC based on November 16, 2009 Public Meeting discussion to address inadequate response to RAI 404-3063, Question 14.03.03-18.