



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION  
Division of Environmental Safety and Health  
Radiation Protection and Release Prevention Element  
Bureau of Nuclear Engineering  
P. O. Box 415  
Trenton, New Jersey 08625-0415  
Tel (609) 984-7700  
Fax (609) 984-7513

JON S. CORZINE  
Governor

MARK N. MAURIELLO  
Acting Commissioner

November 24, 2009

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Dear Commissioners:

Subject: Salem Generating Station Unit 1  
Docket No. 50-272  
License Amendment Request S09-05  
One-Time Extension of the Type A Test Interval

PSEG Nuclear LLC submitted the proposed change to the Salem Technical Specifications by letter to the NRC dated September 21, 2009. This proposed amendment would revise Technical Specification 6.8.4.f, "Primary Containment Leakage Rate Testing Program" to allow a one-time extension of the Type A Integrated Leakage Rate Test (ILRT) interval from 10 years to 15 years.

The BNE has no comments on the proposed change. If you need to discuss this subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Patrick Mulligan, Manager  
Bureau of Nuclear Engineering

A017  
NRR

Distribution

Dr. Jill Lipoti, DEP

Paul Baldauf, DEP

Elliot Rosenfeld, DEP

Nancy McNamara, NRC Region 1

Rick Ennis, NRC Licensing Project Manager

Christine Neely, Director – Regulatory Assurance, PSEG Nuclear LLC

William Mattingly, Regulatory Assurance Manager, Salem Generating Station