

NRCREP Resource

From: Gary Park [gary.park@nexteraenergy.com]
Sent: Monday, November 30, 2009 12:56 PM
To: NRCREP Resource
Subject: Response from "Comment on NRC Documents"

74 FR 61715

11/25/09

①

Below is the result of your feedback form. It was submitted by

Gary Park (gary.park@nexteraenergy.com) on Monday, November 30, 2009 at 12:55:59

Document_Title: NRC Regulatory Issue Summary 2009-xx, Inservice Inspection and Testing Requirements of Dynamic Restraints (Snubbers)

Comments: This RIS will be outdated when the 2006 Addenda is incorporated into 10CFR50.55a. As in the 2006 Addenda of ASME Section XI, IWF-5000 was deleted.

organization: NextEra Energy LLC

address1: 3277 DAEC Road

address2:

city: Palo

state: IA

zip: 52324

country: USA

phone: 3198517792

RECEIVED

2009 DEC -4 PM 1:37

RULES AND DIRECTIVES
BRANCH
11/25/09

SUNSI Review Complete
Template = ADM-013

E-RIDS = ADM-03
Add: G. Bedi (GSB2)