

POWER AUTHORITY OF THE STATE OF
PO BOX 215
BUCHANAN NY 10511



50-286

4-042587S340003 12/05/80 ICS IPMTZZ CSP PHAB
2 9147398200 MGM TDMT BUCHANAN NY 12-05 0350P EST

NUCLEAR REGULATORY COMMISSION
ATTN BOYCE GRIER, DIRECTOR OF REGION 1
OFFICE OF INSPECTION & ENFORCEMENT
631 PARK AVE
KING OF PRUSSIA PA 19406

US NRC
DISTRIBUTION SERVICES
BRANCH

1980 DEC 16 AM 11 06

RECEIVED DISTRIBUTION
SERVICES UNIT

THIS IS A CONFIRMATION COPY OF A PREVIOUSLY PHONE-DELIVERED TELEGRAM

A LEAK HAS BEEN IDENTIFIED IN NUMBER 35 FAN COOLER UNIT AT INDIAN
POINT 3 AT 1000 HOURS TODAY WHILE PLANT WAS IN COLD SHUTDOWN
CONDITION. LEAK RATE IS APPROXIMATELY 1/4 PINT PER MINUTE. LEAK WILL
BE REPAIRED PRIOR TO START UP.

SIGNED S S ZULLA, RESIDENT MANAGER
INDIAN POINT 3 NUCLEAR POWER PLANT
POWER AUTHORITY OF THE STATE OF NEW YORK

PO BOX 215
BUCHANAN NY 10511

15:52 EST

MGMCOMP

M007
S 1/0

8012170361

5