## POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

GEORGE T. BERRY PRESIDENT & CHIEF OPERATING OFFICER

JOHN W. BOSTON EXECUTIVE VICE PRESIDENT—PROCEDURES & PERFORMANCE

JOSEPH R. SCHMIEDER EXECUTIVE VICE PRESIDENT & CHIEF ENGINEER

LEROY W. SINCLAIR SENIOR VICE PRESIDENT & CHIEF FINANCIAL OFFICER

THOMAS R. FREY SENIOR VICE PRESIDENT & GENERAL COUNSEL

November 16, 1981 IPN-81-91

TRUSTEES JOHN S. DYSON CHAIRMAN GEORGE L. INGALLS VICE CHAIRMAN RICHARD M. FLYNN ROBERT I. MILLONZI

FREDERICK R. CLARK

Director of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555 Attention: Mr. Darell G. Eisenhut, Director Division of Licensing Office of Nuclear Reactor Regulation

Subject: Indian Point 3 Nuclear Power Plant Docket No. 50-286 Natural-Circulation Cooldown NOV19 1981 -

Dear Sir:

8111200289 81111 PDR ADDCK 050003

This letter responds to your Generic Letter No. 81-21 dated May 5, 1981, regarding the subject item.

Following the St. Lucie Unit No. 1 cooldown event of June 11, 1980, I.E. Circular 80-15 was issued to address your items of concern. Subsequently, the Westinghouse Owners Group (W-OG), of which the Authority is a member, undertook a study with Westinghouse to evaluate the potential for steam void formation in Westinghouse designed NSSS during natural circulation cooldown and depressurization transients, and to develop appropriate modifications to operating instruction guidelines. This study has been completed and a summary report was submitted to the NRC via Owners Group letter OG-57 dated April 20, 1981.

After reviewing the W-OG study, the Authority has modified the natural circulation cooldown procedure to reflect the new operating guidelines and findings. Also, a plant analysis demonstrated that the Technical Specification limit on minimum Condensate Storage Tank level provides sufficient inventory to support the revised natural circulation cooldown procedure.



A001 510 The Authority has incorporated the natural circulation cooldown as a part of the licensed operator retraining program. Also, simulator exercises, for conditions which require a controlled cooldown on natural circulation and when rapid depressurization is not necessary, were administered to licensed personnel as part of the overall simulator lesson plan.

Should you or your staff have any questions, please contact us.

Very truly yours,

J.P. Bayne Senior Vice President Nuclear Generation

State of New York County of New York

Subscribed and sworn to before me this 16 day of November 1981.

/Notary Publ//

RUTH G. ZAPF Notary Public, State of New York No. 30-4663428 Qualified in Nassau County Commission Expires March 30, 19

cc: Mr. T. Rebelowski
 Resident Inspector
 U.S. Nuclear Regulatory Commission
 P.O. Box 38
 Buchanan, New York 10511

Mr. Ron Barton
United Engineers & Constructors, Inc.
30 S. 17th Street
Philadelphia, PA 19101