

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

TRUSTEES

JOHN S. DYSON
CHAIRMAN

GEORGE L. INGALLS
VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

FREDERICK R. CLARK



GEORGE T. BERRY
PRESIDENT & CHIEF
OPERATING OFFICER

JOHN W. BOSTON
EXECUTIVE VICE
PRESIDENT—PROCEDURES
& PERFORMANCE

JOSEPH R. SCHMIEDER
EXECUTIVE VICE
PRESIDENT & CHIEF
ENGINEER

LEROY W. SINCLAIR
SENIOR VICE PRESIDENT
& CHIEF FINANCIAL
OFFICER

THOMAS R. FREY
SENIOR VICE PRESIDENT
& GENERAL COUNSEL

November 17, 1981
IPN-81-92

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
Control of Heavy Loads



Dear Sir:

Your letter dated July 31, 1980 requested a review of the controls for handling heavy loads at the Indian Point 3 Nuclear Power Plant, the implementation of certain recommendations regarding these controls, and the submittal of information to demonstrate that the recommendations have been implemented.

By letter dated June 22, 1981 (IPN-81-43), the Authority provided you with the information requested in Section 2.1 of Enclosure 3 to your July 31, 1980 letter. As indicated in the Authority's September 25, 1981 (IPN-81-72) letter and as discussed with Mr. Thoma, the NRC Project Manager for the Indian Point 3 Nuclear Power Plant, the Authority provides, herewith, the information requested in Sections 2.2, 2.3 and 2.4 of Enclosure 3 to your July 31, 1980 letter.

In the Authority's June 22, 1981 report, it was indicated that it was necessary to confirm that certain criteria in ANSI N14.6-1978 were met for the Reactor Vessel Head and Internal Lifting Rigs. We have reevaluated our previous response (item 3.d) on these devices and have determined that the information provided is sufficient to demonstrate adequate load handling reliability for these devices.

A033
S
/11

8111240366 811117
PDR ADOCK 05000286
P PDR

This submittal completes our response to all requests for information in your July 31, 1980 letter. Should you or your staff have any questions please contact us.

Very truly yours,

C. M. Wilverding

fn
J. P. Bayne
Senior Vice President
Nuclear Generation

Attachment

cc: Resident Inspector
Indian Point Unit 3
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, New York 10511

Mr. Ron Barton
United Engineers & Constructors, Inc.
30 S. 17th Street
Philadelphia, Pa. 19101