

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

TRUSTEES

JOHN S. DYSON
CHAIRMAN

GEORGE L. INGALLS
VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

FREDERICK R. CLARK



GEORGE T. BERRY
PRESIDENT & CHIEF
OPERATING OFFICER

JOHN W. BOSTON
EXECUTIVE VICE
PRESIDENT & DIRECTOR
OF POWER OPERATIONS

JOSEPH R. SCHMIEDER
EXECUTIVE VICE
PRESIDENT & CHIEF
ENGINEER

LEROY W. SINCLAIR
SENIOR VICE PRESIDENT
& CHIEF FINANCIAL
OFFICER

THOMAS R. FREY
SENIOR VICE PRESIDENT
& GENERAL COUNSEL

May 11, 1982
IPN-82-40

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
Control Room Human Factors Review

Dear Sir:


This letter provides the solution selected by the Authority regarding the control room switch position nomenclature.

By letter dated 5/1/81 (IPN-81-31), the Authority committed to choose and implement a solution to resolve the concerns related to long term item (e) of your 10/31/80 letter.

Attachment I lists those switches for which the Authority will affix conspicuous labels on the control room panel to indicate unconventional switch position nomenclature. They will be installed prior to start-up from the current refueling outage.

Should you or your staff have any questions, please contact us.

Sincerely,


J.P. Bayne
Senior Vice President
Nuclear Generation

cc: attached

8205180 423

App 1
3
1/1

ATTACHMENT I

Listing of Switches for Which
Labels will be Provided

| <u>Panel Location</u> | <u>Function (Qty.)</u> |
|-----------------------|--|
| SCF | Blowdown Isolation Valves (8) |
| SBF-1 | SI Pump Suction Low Pressure Block (1) |
| SBF-1 | Main Steam Isolation Valves (4) |
| FAF | Stop Valve (Test) - Upper Left (1) |
| | Upper Right (1) |
| | Lower Left (1) |
| | Lower Right (1) |
| | Load Limit Valve No. 1 (1) |
| | Load Limit Valve No. 2 (1) |
| | Governor Speed Changer (1) |
| | Regulator Base Adjust (1) |
| | Boiler Feed Pump Governor No. 31 (1) |
| | Boiler Feed Pump Governor No. 32 (1) |

cc: Mr. W. H. Baunack, Acting Chief
Indian Point
U.S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, New York 10511

Mr. T. J. Kenny, Resident Inspector
Indian Point Unit 3
U.S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, New York 10511

Mr. Ron Barton
United Engineers & Constructors, Inc.
30 S. 17th Street
Philadelphia, Pa. 19101