POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019 (212) 397.6200

TRUSTEES

JOHN S. DYSON CHAIRMAN

GEORGE L. INGALLS VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

FREDERICK R. CLARK



November 10, 1982 IPN-82-73

Director of Nuclear Reactor Regulation U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Attention: Mr. Steven A. Varga, Chief Operating Reactor Branch No. 1 Division of Licensing

Subject:

Docket No. 50-286 Request for Additional Information Concerning Action Plant Item 11.K.3.17 Report on Outages of ECC Systems

Indian Point 3 Nuclear Power Plant

Dear Sir:

In response to your June 25, 1982 letter the Authority provides herewith, in Attachment A, the requested additional information concerning ECCS Systems outages. The Authority understands that the information provided in this letter will be used to determine the cumulative duration of ECCS outages. It must be recognized that the data provided overstates the actual required outage time considerably. Many maintenance actions cited in Table 2 were discretionary in their timing and were performed when the system was not required to be operational. Therefore the work was performed on a low priority basis.

The information concerning diesel generator outages is contained in the Authority's letter of November 19, 1981 (IPN-81-93) which was in response to your letter dated July 20, 1981 regarding Unresolved Safety Issue A-44, Station Blackout.

Should you or your staff have any questions please contact Mr. P. Kokolakis of my staff.

Very truly yours,

Wilvadin

J. P. Bayne Executive Vice President Nuclear Generation

A046

Att.

cc: attached



LEROY W. SINCLAIR PRESIDENT & CHIEF OPERATING OFFICER

WALTER T. KICINSKI FIRST EXECUTIVE VICE PRESIDENT & CHIEF ADMINISTRATIVE OFFICER

JOSEPH R. SCHMIEDER EXECUTIVE VICE PRESIDENT & CHIEP ENGINEER

JOHN W. BOSTON EXECUTIVE VICE PRESIDENT PROCEDURES & PERFORMANCE

THOMAS R. FREY SENIOR VICE PRESIDENT & GENERAL COUNSEL cc: Resident Inspector's Office Indian Point Unit 3 U. S. Nuclear Regulatory Commission P. O. Box 38 Buchanan, New York 10511

(.

ATTACHMENT A

Response to Request for Additonal Information Concerning Action Plan Item II.K.3.17 Report on Outages of ECC Systems

POWER AUTHORITY OF THE STATE OF NEW YORK INDIAN POINT 3 NUCLEAR POWER PLANT DOCKET NO. 50-286 NOVEMBER, 1982

ATTACHMENT A

Item II.K.3.17 ECC System Outages

The purpose of this report is to provide information to the NRC on the possible unreliability of the ECC Systems and to determine if cumulative outage limitations are needed. It should be noted that the Indian Point 3 technical specifications require only a portion of the ECC system to be operational during cold shutdown conditions and only during specified evolutions.

The report on ECC System Outages is provided under the following conditions:

- 1. The equipment investigated was that identified as ECC equipment in the Indian Point 3 FSAR, Section 6.2.
- 2. The period investigated was from initial criticality, April 6,1976 to December 31, 1980.
- 3. Outage times resulting from testing were developed in the following manner:
 - a. Periodic tests performed on ECC components which prevented the component from performing it's designed function in the intended manner, were identified and listed.
 - b. Tests performed on ECC components after completion of maintenance were identified and listed.
 - c. An estimate of the time required to perform each of these tests was determined. The total estimated time that various ECC system components were tested is tabulated on Table 1.
- 4. ECC system maintenance outages were identified through research of the Maintenance Work Request (WR) records. Work request documents indicate when maintenance is first requested and when maintenance is completed. The reported timestabulated on Table 2 are estimates of when the equipment was out of service for maintenance. It should be noted that work done during cold shutdown is performed at a time when the ECC Systems are not required by technical specifications and therefore there is no impetus to complete the work on an accelerated schedule.

and the second second second second

TABLE 1

ECC Systems Testing Outages, April 6, 1976 to December 31, 1980

Residual Heat Removal (RHR) System Testing

DATE	-	COLD SHUTDOWN	ABOVE COLD SHUTDOWN
Quarterly	Testing		
4/15/80		-	0.1 hour
6/24/80		-	0.1 hour
9/18/80		-	0.1 hour
12/8/80		0.1 hour	-
	TOTAL	0.1 hours	0.3 hours
Refueling	Testing		
8/9/78		l hour	-
8/12/78		1	-
8/13/78		1	-
8/14/78		5	-
11/9/79		4	-
12/7/79		1	-
12/12/79		1	-
12/17/79		1	-
12/27/79		1	-
10/1/80		1	-
	TOTAL	17 hours	
Cold Shutd	own Testing		
7/29/80		1	
12/3/80		1	-
12/17/80		1	-
	TOTAL	3 hours	
Variable T	estina		

 8/14/78
 1

 3/26/79
 1

 1/22/80
 1

 TOTAL
 3 hours

RHR System Testing - Cont'd

DATE		COLD SHUTDOWN	ABOVE COLD SHUTDOWN
Retests		· .	
12/7/79		2 hours	-
12/27/79		2	-
7/29/80		1	-
11/5/80			2 hours
11/30/80		-	2
12/1/80		1	-
12/16/80		1	-
	TOTAL	7 hours	4 hours

1-2

Safety Injection System Testing

DATE		COLD SHUTDOWN	ABOVE COLD SHUTDOWN
Refueling Tes	sting	• · · ·	
8/13/78		2.5 hours	-
12/14/79		1	-
12/17/79		1.5	-
11/2/80		1	-
	TOTAL	6 hours	
Cold Shutdown	n Testing		
10/27/80		0.2 hours	-
	TOTAL	0.2 hours	
Retests			
11/6/79		2 hours	-
12/27/79		1	-
12/28/79		2	-
8/11/80		1	- ·
12/16/80		2	-
	TOTAL	8 hours	

Accumulator Testing

DATE		COLD SHUTDOWN *	ABOVE COLD SHUTDOWN		
Refueling Te	Refueling Testing				
7/13/78		4	-		
11/1/78		4	-		
	TOTAL	8 hours			
Cold Shutdow	n Testing				
7/29/80		1.3 hours	-		
12/3/80		1.3	-		
12/17/80		1.3	-		
	TOTAL	3.9 hours			
Variable Tes	ting				
4/8/77		1.3 hours	-		
8/14/78		1.3	-		
3/26/79		1.3	-		
12/3/79		1.3	-		
1/22/80		1			
	TOTAL	6.2 hours			
Retest					
11/18/80 \		1	-		

TOTAL 19.10 hours

* Accumulators are isolated from the RCS when the RCS pressure is less than 1000 psig during normal plant operation.

Boron Injection Tank Testing

DATE		COLD SHUTDOWN	ABOVE COLD SHUTDOWN		
Refueling Tes	Refueling Testing				
8/9/78		l hour	-		
12/12/79		1			
	TOTAL	2 hours			
Cold Shutdown	Testing				
10/27/80		0.2 hours	-		
	TOTAL	0.2 hours			
Retests					
12/28/79		2 hours	-		
	TOTAL	2 hours			

.

1-5

ι.

1

Alexandro a construction and a second se Alexandro a construction and a second Alexandro a construction and a second sec

Recirculation Pumps Testing

DATE	۰.	COLD SHUTDOWN	ABOVE COLD SHUTDOWN
Refueling Tes	ting	• .	
8/13/78		l hour	-
12/17/79		1	-
	TOTAL	2 hours	

TABLE	2
	~

ECC Systems Testing Outages, April 6, 1976 to December 31, 1980

-

		Cold Shutdown (hours)	Above Cold Shutdown (hours)
Component	Boron Injection Tank		(110 41 0)
Outage dates	9/19/76 to 9/30/76		
Duration		262	_
Cause	Corroded weld on outlet line		
Corrective Action	Defective weld repaired		
Component	#31 Safety Injection Pump		
Outage dates	4/4/77 to 4/7/77		
Duration		. -	68
Cause	Low discharge pressure		
Corrective Action	Replaced pump internals		
Component	Safety Injection Valves 856B,		
Outage dates	11/8/77		
Duration		20	_
Cause	Valve leaks		
Corrective Action	Repack valves		
Component	#32 Residual Heat Removal Pump	þ	
Outage dates	11/23/77 to 12/2/77		
Duration		240	-
Cause	Seal water supply leak		
Corrective Action	Repaired leak at seal package		
Component	#31 Residual Heat Removal Pump		
Outage dates	3/28/78 to 3/29/78		
Duration		-	8
Cause	Seal housing leak		
Corrective Action	Raised seal housing and replac gasket	ed	

1.11

. : .*

Table 2 cont'd Above Cold Cold Shutdown Shutdown (hours) (hours) Component #31 RHR Pump Outage dates 6/13/78 Duration 20 Comment Modification to provide an emergency cooling water supply Component #32 RHR Pump Outage dates 8/15/78 to 8/16/78 Duration 24 Cause Seal leakage Corrective Action Replaced mechanical seal Component RHR Valve 897A Outage dates 12/11/78 to 12/12/78 Duration 20 Cause Valve cover leak Corrective Action Replaced gasket and performed general maintenance Component RHR Valve 838D Outage dates 11/3/79 to 11/5/79 Duration 48 Cause Valve gasket leak Corrective Action Repaired gasket Component #32 RHR Pump Outage dates 11/9/79 to 11/10/79 second sector Duration 24 Cause Seal leakage Corrective Action Replace mechanical seal Component Safety Injection Valve 856A Outage dates 12/30/79 to 12/31/79 Duration 24

Improper valve operation Replaced limitorque operation

> . Nersky, solar i

ويحط جرره

a seco

2-2

Cause

Corrective Action

Table 2 cont'd



