



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 16, 2009

Mr. Christopher R. Costanzo
Vice President
Duane Arnold Energy Center
3277 DAEC Road
Palo, IA 52324-9785

SUBJECT: DUANE ARNOLD ENERGY CENTER – CLOSEOUT OF GENERIC LETTER
2008-01 “MANAGING GAS ACCUMULATION IN EMERGENCY CORE
COOLING, DECAY HEAT REMOVAL, AND CONTAINMENT SPRAY
SYSTEMS” (TAC NO. MD7824)

Dear Mr. Costanzo:

On January 11, 2008, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2008-01, “Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems” (Agencywide Documents Access and Management System (ADAMS) Accession No. ML072910759). The stated purpose of GL 2008-01 was (a) to request addressees to submit information to demonstrate that the subject systems are in compliance with the current licensing and design bases and applicable regulatory requirements, and that suitable design, operational, and testing control measures are in place for maintaining this compliance; and, (b) to collect the requested information to determine if additional regulatory action is required.

GL 2008-01 requested that licensees provide the following information within 9 months of the date of the GL:

- (a) A description of the results of evaluations that were performed pursuant to requested actions specified in the GL. This description should provide sufficient information to demonstrate that you are or will be in compliance with the quality assurance criteria in Sections III, V, XI, XVI, and XVII of Appendix B to 10 CFR Part 50 and the licensing basis and operating license as those requirements apply to the subject systems;
- (b) A description of all corrective actions, including plant, programmatic, procedure, and licensing basis modifications that you determined were necessary to assure compliance with these regulations; and,
- (c) A statement regarding which corrective actions were completed, the schedule for completing the remaining corrective actions, and the basis for that schedule.

In your letters dated October 13, 2008, April 27, 2009, and October 16, 2009, (ADAMS Accession Nos. ML082970263, ML091250298 and ML093000152 respectively), you provided information in response to the GL. The NRC staff has reviewed the submitted information and has concluded that for Duane Arnold your response to the GL is acceptable. Consequently, your GL response is considered closed and no further information or action is requested of you. Notwithstanding, the NRC’s Region III staff may decide to perform (and would contact you to schedule) an inspection using Temporary Instruction (TI) 2515/177,

C. Costanzo

- 2 -

"Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems (NRC Generic Letter 2008-01)" (ADAMS Accession No. ML082950666). The TI 2515/177 is confirmatory in nature in that it directs NRC inspectors to selectively verify that the licensee has implemented, or is in the process of acceptably implementing, the commitments, modifications, and programmatically controlled actions described in the licensee's response to GL 2008-01, and the plant-specific information supports a conclusion that subject systems operability is reasonably ensured.

If you have any questions regarding this letter, please feel free to contact me at (301) 415-3079.

Sincerely,

A handwritten signature in cursive script that reads "Karl Feintuch".

Karl Feintuch, Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-331

cc: Distribution via Listserv

“Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems (NRC Generic Letter 2008-01)” (ADAMS Accession No. ML082950666). The TI 2515/177 is confirmatory in nature in that it directs NRC inspectors to selectively verify that the licensee has implemented, or is in the process of acceptably implementing, the commitments, modifications, and programmatically controlled actions described in the licensee’s response to GL 2008-01, and the plant-specific information supports a conclusion that subject systems operability is reasonably ensured.

If you have any questions regarding this letter, please feel free to contact me at (301) 415-3079.

Sincerely,

/RA/

Karl Feintuch, Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-331

cc: Distribution via Listserv

DISTRIBUTION:

PUBLIC	LPL3-1 r/f	RidsNrrDorlDpr Resource	RidsNrrDorlLpl3-1 Resource
RidsAcrsAcnw_MailCTR Resource		RidsNrrLATHarris Resource	RidsOgcRp Resource
RidsNrrDirsltsb Resource		RidsRgn3MailCenter Resource	MRazzaque, NRR
RidsNrrPMDuaneArnold Resource		WLyon, NRR	DBeaulieu, NRR

ADAMS ACCESSION NO.: ML093431085

*Memo dated 12/4/09

OFFICE	NRR/LPL3-1/ PM	NRR/LPL3-1/ LA	NRR/SRXB/BC*	NRR/LPL3-1/ BC
NAME	KFeintuch	THarris	GCranston	RPascarelli
DATE	12/14/09	12/10/09	12/04/09	12/16/09

OFFICIAL RECORD COPY