

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

TRUSTEES

JOHN S. DYSON  
CHAIRMAN  
  
GEORGE L. INGALLS  
VICE CHAIRMAN  
  
RICHARD M. FLYNN  
  
ROBERT I. MILLONZI  
  
JAMES L. LAROCCA



January 26, 1983  
IPN-83-8

LEROY W. SINCLAIR  
PRESIDENT & CHIEF  
OPERATING OFFICER

WALTER T. KICINSKI  
FIRST EXECUTIVE  
VICE PRESIDENT &  
CHIEF ADMINISTRATIVE  
OFFICER

JOSEPH R. SCHMIEDER  
EXECUTIVE VICE  
PRESIDENT & CHIEF  
ENGINEER

STEPHEN L. BAUM  
SENIOR VICE PRESIDENT  
& GENERAL COUNSEL

Director of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. Steven A. Varga, Chief  
Operating Reactors Branch No. 1  
Division of Licensing

Subject: Indian Point 3 Nuclear Power Plant  
Docket No. 50-286  
Questions Concerning the Indian Point 3  
Emergency Operations Facility

Dear Mr. Varga:

Pursuant to the NRC staff's request of December 2, 1982, for information regarding the Indian Point 3 Emergency Operations Facility (EOF) and Alternate Emergency Operations Facility (AEOF), the Authority provides the following information in writing.

The permanent primary near site EOF for IP-3 is located in the main building of the Con Edison Buchanan Service Center Complex on Broadway just south of the Bleakley Avenue intersection. This building is a completed structure. The walls of the building are constructed of concrete blocks which provide a protection factor greater than 5. The roof is made up of corrugated steel and has a protection factor less than 5. The EOF does not contain a HEPA filtration system, but the ability to isolate the EOF ventilation system and recirculate the air internally does exist. Construction on the refurbished EOF was started the week of June 13, 1980.

The interim AEOF is located at the Con Edison Eastview Service Center on Old Saw Mill River Road in Greenburgh, New York, which is approximately 16 miles from IP-3. It is constructed mainly of cinder blocks and glass. Construction was started and completed in 1955.

A045

8302030424 830126  
PDR ADDCK 05000286  
F PDR

As stated in our letter of September 13, 1982 to George Smith of the NRC, the permanent AEOF will be located in our office at 123 Main Street, White Plains, New York.

Should you or your staff have any questions, please contact Mr. P. Kokolakis of my staff.

Very truly yours,



J. P. Bayne  
Executive Vice President  
Nuclear Generation

cc: Resident Inspector's Office  
Indian Point Unit 3  
U.S. Nuclear Regulatory Commission  
P.O. Box 66  
Buchanan, New York 10511