

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE

NEW YORK, N.Y. 10019

(212) 397-6200

TRUSTEES

JOHN S. DYSON

CHAIRMAN

GEORGE L. INGALLS

VICE CHAIRMAN

RICHARD M. FLYNN

JAMES L. LARocca

ROLLAND E. KIDDER



LEROY W. SINCLAIR
PRESIDENT & CHIEF
OPERATING OFFICER

WALTER T. KICINSKI
FIRST EXECUTIVE
VICE PRESIDENT &
CHIEF ADMINISTRATIVE
OFFICER

JOSEPH R. SCHMIEDER
EXECUTIVE VICE
PRESIDENT & CHIEF
ENGINEER

STEPHEN L. BAUM
SENIOR VICE PRESIDENT
& GENERAL COUNSEL

May 20, 1983
IPN-83-47

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
Confirmation of Telephone Discussion

Dear Sir:

This letter serves to document recent telephone discussion between the Authority and members of your Staff with regard to seismic qualification documentation for the auxiliary feedwater (AFW) system and proposed fire protection technical specifications.

As requested by members of the NRC Staff, the Authority hereby commits to submittal of the results of the AFW System document search (reference: IPN-83-11, dated February 7, 1983) within sixty (60) days after startup from the current outage.


Regarding the proposed fire protection technical specifications requested in Mr. Varga's letter dated April 21, 1983, the Authority will submit technical specifications requiring quarterly surveillance of the alternate electrical feed system. This test will energize the feeders and verify power available to the instrumentation isolation cabinet, backup service water pump, charging pumps and component cooling water pump. Transfer switches will be tested during refueling outages. Transmittal of a formal License Amendment request, including the proposed technical specifications requested in Mr. Varga's letter Dated April 21, 1983, will be submitted prior to exceeding 5% rated power during startup from the current outage.

A001

8305240234 830520
PDR ADDCK 05000286
F PDR

Should you or your staff have any questions regarding this matter, please contact Mr. P. Kokolakis of my staff.

Very truly yours,


J. P. Bayne
Executive Vice President
Nuclear Generation

cc: Resident Inspector's Office
Indian Point 3
U. S. Nuclear Regulatory Commission
P. O. Box 66
Buchanan, New York 10511