



**J. Phillip Bayne**  
Executive Vice President  
Nuclear Generation

November 30, 1983  
IPN-83-96

Director of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. Steven A. Varga, Chief  
Operating Reactors Branch No. 1  
Division of Licensing

Subject: Indian Point 3 Nuclear Power Plant  
Docket No. 50-286  
Seismic Qualification of the Auxiliary  
Feedwater System (AFS)

Dear Sir:

This letter is a follow up to our previous letter dated August 11, 1983 (IPN-83-71) concerning the seismic qualification of the AFS turbine driven pump automatic speed control system.

The Authority has performed a seismic analysis of the speed control system. The results of this analysis indicate that the speed control system is seismically qualified and, therefore, no corrective action is required to the system.

Should you or your staff have any questions regarding this matter, please contact Mr. P. Kokolakis of my staff.

Very truly yours,

*C. M. Walrod*

*fn*  
J. P. Bayne  
Executive Vice President  
Nuclear Generation

cc: Resident Inspector's Office  
Indian Point Unit 3  
U. S. Nuclear Regulatory Commission  
P. O. Box 66  
Buchanan, New York 10511

8312060096 831130  
PDR ADOCK 05000286  
PDR

Acc 1  
/10