



November 14, 1984
IPN-84-56

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
Steam Generator Tube Inspection Results

Dear Sir:

Enclosed for your review, please find a summary of the results of the recent eddy current testing of the Indian Point 3 steam generators. This testing encompassed 100% of the tubes on both the hot leg and cold leg sides for each of the four steam generators.

Should you or your staff have any questions regarding this matter, please contact Mr. P. Kokolakis of my staff.

Very truly yours,

A handwritten signature in cursive script that reads 'J.P. Bayne'.

fn
J.P. Bayne
First Executive Vice President
Chief Operations Officer

cc: Resident Inspector's Office
Indian Point 3
U.S. Nuclear Regulatory Commission
P.O. Box 66
Buchanan, New York 10511

8411200214 841114
PDR ADDCK 05000286
Q PDR

A047
11

INDIAN POINT 3
NEW YORK POWER AUTHORITY

CURRENT STEAM GENERATOR TUBE STATUS
(CRITICAL SIZE RANGES - 63% PLUGGING LIMIT)

<u>PROGRAM DESCRIPTION</u>	<u>EXTENT COMPLETE</u>	<u>NUMBER OF DEGRADED TUBES</u>		
		<u>< 63%</u>	<u>≥ 63%</u>	<u>TOTAL</u>
31 OUTLET	100%	226	8	234
32 OUTLET	100%	222	5	227
33 OUTLET	100%	184	5	189
34 OUTLET	100%	246	6	252

<u>PROGRAM DESCRIPTION</u>	<u>EXTENT COMPLETE</u>	<u>NUMBER OF DEGRADED TUBES</u>		
		<u>< 40%</u>	<u>≥ 40%</u>	<u>TOTAL</u>
31 INLET	100%	48	13	61
32 INLET	100%	15	4	19
33 INLET	100%	29	8	37
34 INLET	100%	9	11	20