



July 3, 1987
IPN-87-034

John C. Brons
Executive Vice President
Nuclear Generation

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

SUBJECT: Indian Point Unit 3 Nuclear Power Plant
Docket No. 50-286
Steam Generator Inspection Results

REFERENCE: 1) Letter from W. A. Josiger to William T. Russell,
dated June 5, 1987 (IP3-WAJ-034), entitled:
"Indian Point 3 Nuclear Power Plant Cycle 5/6
Inspection of Steam Generators."

Dear Sir:

Reference 1 reported that steam generators 31, 32 and 33 had been classified category C-3 based on the results of the steam generator tube eddy current (ECT) inspection. Therefore, in accordance with Indian Point 3 Technical Specification Table 4.9, Attachment 1 to this letter describes the results of the steam generator tube eddy current inspection. The report provides sufficient information for the NRC to review and approve unit startup for cycle 6 operation. Additionally it describes corrective measures being taken to prevent the recurrence of tube degradation.

Attachments 2 and 3 provide a listing of ECT indications and tubes which were plugged for all four steam generators also in accordance with Technical Specification 4.9.


This letter requests review of the attached data and approval for plant startup for cycle 6 operations. Startup is scheduled for July 21, 1987 and thus expeditious review and approval is requested.

8707090406 870703
PDR ADDCK 05000286
Q PDR

Limited Distribution
A047
1/1

Should you have any questions regarding this matter, please contact Mr. P. Kokolakis of my staff.

Very truly yours,


John C. Brons
Executive Vice President
Nuclear Generation

Attachments

cc: Resident Inspector's Office
Indian Point Unit 3
U.S. Nuclear Regulatory Commission
P.O. Box 377
Buchanan, NY 10511

Ms. Marylee M. Slosson, Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, MD 20014

Mr. William T. Russell
Regional Administrator - Region 1
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Joseph D. Neighbors, Senior Project Manager
PWR Project Directorate I-1
Division of Reactor Projects I/II
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, MD 20014