



**New York Power  
Authority**

February 10, 1989  
IPN-89-010

**John C. Brons**  
Executive Vice President  
Nuclear Generation

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

**Subject:** Indian Point 3 Nuclear Power Plant  
Docket No. 50-286  
**Weld and Support Program;**  
**Inservice Inspection Second 10-Year Interval**


Dear Sir:

Attached for your review is the Indian Point Unit No. 3 Weld and Support Inservice Inspection (ISI) Plan. It is prepared in accordance with the ASME Boiler and Pressure Vessel Code, Section XI, 1983 Edition through the 1983 Summer Addenda including applicable relief requests per 10 CFR 50.55a(g)(5). This plan outlines the ISI requirements for ISI Class 1 and 2 components, piping and their supports including relief requests from the Code where applicable. It covers the second 10-Year ISI interval from August 31, 1986 through August 31, 1996.

The final inspection period of the first 10-Year inservice inspection interval (August 31, 1976 to August 31, 1986) extended into 1987 based on an interval extension of one year as allowed by paragraph IWA-2400(a) of the ASME Code, 1974 Edition (with Summer 1975 Addenda). This extension permitted inspections to be conducted concurrently with a scheduled plant outage. The final inspection period of the first 10-Year interval overlapped with the first inspection period of the second 10-Year interval. This overlap ended September 1987, with the conclusion of the Cycle 5/6 refueling outage.

Should you or your staff have any questions regarding this letter please contact Mr. P. Kokolakis of my staff.

Very truly yours,

  
John C. Brons  
Executive Vice President  
Nuclear Generation

Attachment  
cc: next page

8902230232 890210  
PDR ADDCK 050002 86  
PIC

A047  
1/1  
1/16

cc: U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Resident Inspector's Office  
Indian Point Unit 3  
U.S. Nuclear Regulatory Commission  
P.O. Box 337  
Buchanan, N.Y. 10511

Joseph D. Neighbors, Sr. Proj. Mgr.  
Project Directorate I-1  
Division of Reactor Projects I/II  
U.S. Nuclear Regulatory Commission  
Mail Stop 14B2  
Washington, D.C. 20555