

Joseph E. Russell Resident Manager

January 24, 1990 IPO-90JB-009 IP3-90-007

Docket No. 50-286 License No. DPR-64

Director, Office of Nuclear Regulatory Research Nuclear Regulatory Commission Washington, D.C. 20555

Dear Sir,

The enclosed report is provided in accordance with the requirements of Section 20.407 of Title 10 Code of Federal Regulations and the requirements of Indian Point 3 Technical Specifications.

This report covers the period January 1, 1989 through December 31, 1989. Please note that the totals listed are based on thermoluminescent dosimeter (TLD) readings.

Very truly yours,

Joseph E. Russell Resident Manager

Indian Point 3 Nuclear Power Plant

Attachment JB/po

cc: IP-3 NRC Resident Inspector's Office

Mr. William T. Russell, Regional Administrator Region 1, U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Document Control Desk (original) U.S. Nuclear Regulatory Commission Washington, DC 20555

9002080296 891231 PDR ADOCK 05000286 R PDC 1856

## PERSONNEL WHOLE BODY EXPOSURE FOR CALENDAR YEAR 1989

New York Power Authority Indian Point #3 Nuclear Station Post Office Box 215 Buchanan, New York 10511

Annual Dose Ranges* (Rem)			of Individuals Each Range
No Measurable Exposure			871
Measurable Exposure < 0.10		•	531
0.10 - 0.25			300
0.25 - 0.50		•	301
0.50 - 0.75		•	228
0.75 - 1.00			147
1.00 - 2.00			263
2.00 - 3.00		•	29
3.00 - 4.00			1 1
4.00 - 5.00			0
5.00 - 6.00			<b>0</b> ,
6.00 - 7.00			0
7.00 - 8.00			0
8.00 - 9.00	·	·.	0
9:00 - 10.00			0
10.00 - 11.00			0
11.00 - 12.00			0
12.00 +			0

Total number of individuals reported: 2671

The above information is submitted for the total number of individuals for whom personnel monitoring was provided during the calendar year.

<sup>\*</sup> Individual values exactly equal to the value separating exposure ranges are reported in the higher range.