

APR 09 1990

Docket No. 50-286

Power Authority of the State of New York  
Indian Point 3 Nuclear Power Plant  
ATTN: Mr. Joseph Russell  
Resident Manager  
P.O. Box 215  
Buchanan, New York 10511

Gentlemen:

Subject: 7-Day Requirements For Emergency Diesel Generator Fuel Oil

This letter refers to your letter dated April 3, 1990, in response to our conference calls conducted on March 29, 1990 and March 30, 1990.

We have reviewed your response to our concerns regarding the onsite tanker truck and the fuel oil storage tank at the Buchanan substation. We understand that you have taken corrective actions to address our concerns. Based on these actions we have no immediate safety concerns regarding this issue and we do not consider this a start up issue. We have also reviewed your position regarding previous NRC acceptance of your current configuration. We have referred this matter to the Office of NRR for their evaluation. We will notify you of the results of this study in the future.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:  
Marvin W. Hodges

Marvin W. Hodges  
Division of Reactor Safety

*m/A-4  
eck*

OFFICIAL RECORD COPY

50-286 7-DAY FO - 0001.0.0  
04/06/90

9004180019 900409  
FDR ADOCK 05000286  
F PDC

IE:01 1/0

APR 09 1990

Power Authority of the  
State of New York


2

cc w/encl:


J. Bayne, President  
J. Brons, Executive Vice President - Nuclear Generation  
G. Goldstein, Assistant General Counsel  
A. Klausmann, Senior Vice President, Appraisal and Compliance Services  
G. Wilverding, Manager, Nuclear Safety Evaluation  
C. Jackson, Manager, Regulatory Affairs  
R. Beedle, Vice President Nuclear Support  
W. Josiger, Vice President Nuclear Operations and Maintenance  
S. Zulla, Vice President Nuclear Engineering  
P. Kokolakis, Director Nuclear Licensing - PWR  
D. Halama, Quality Assurance Superintendent  
M. Peckham, Assistant to Resident Manager  
Dept. of Public Service, State of New York  
State of New York, Department of Law  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of New York, SLO Designee

bcc w/encl:


Region I Docket Room (with concurrences)  
R. Bellamy, DRSS  
J. Linville, DRP  
D. Limroth, DRP  
G. Meyer, DRP  
W. Schmidt, SRI - Fitzpatrick  
F. Crescenzo, SRI Indian Point 2  
J. Neighbors, NRR  
J. Dyer, EDO

  
RI:DRS  
Anderson

4/8/90

  
RI:DRS  
Durr

4/8/90

  
RI:DRS  
Hodges

4/9/90

OFFICIAL RECORD COPY

50-286 7-DAY FO - 0001.1.0  
04/06/90