

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001



**New York Power
Authority**

Joseph E. Russell
Resident Manager

January 14, 1992
IP3-NRC-92-004

Docket No. 50-286
License No. DPR-64

Mr. Thomas T. Martin
Regional Administrator, Region 1
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Dear Sir:

The enclosed report is provided in accordance with the requirements of Indian Point 3 Technical Specifications and Regulatory Guide 1.16.

The enclosure contains the report of personnel radiation exposure by work and job function.

This report covers the period January 1, 1991 through December 31, 1991. Please note that the totals listed are based on thermoluminescent dosimeter (TLD) readings. The breakdown of dose by category was based on pocket dosimeter (ion chamber) readings and adjusted to equal the record TLD doses. The TLD readings were approximately 59% of the pocket dosimeter totals for 1991 on an average annual basis.

Very truly yours,

A handwritten signature in black ink, appearing to read 'J. E. Russell', written over a large, stylized cursive flourish.

Joseph E. Russell
Resident Manager
Indian Point 3 Nuclear Power Plant

JER:JB:po
Attachment

9201240269 920114
PDR ADCK 05000286
R PDR

IF56
11

cc: Document Control Desk (original)
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Resident Inspector's Office
Indian Point 3
US Nuclear Regulatory Commission
PO Box 337
Buchanan, N.Y. 10511

New York Power Authority
 Indian Point #3 Nuclear Station
 Post Office Box 215
 Buchanan, N.Y. 10511

1991 ANNUAL REPORT

NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

WORK & JOB FUNCTION	Number of Personnel [> 100 mrem]			Total Man-Rem		
	Station Employees	Utility Employees	Contractors and others	Station Employees	Utility Employees	Contractors and Others
Reactor Oper & Surveillance						
Maintenance Personnel	4	0	0	.40	.00	.00
Operating Personnel	45	0	2	5.88	.00	.20
Health Physics Personnel	27	0	5	6.76	.00	.57
Supervisory Personnel	5	0	0	.69	.00	.00
Engineering Personnel	4	0	0	.65	.00	.00
Routine Maintenance						
Maintenance Personnel	0	0	0	.00	.00	.00
Operating Personnel	0	0	0	.00	.00	.00
Health Physics Personnel	0	0	0	.00	.00	.00
Supervisory Personnel	0	0	0	.00	.00	.00
Engineering Personnel	0	0	0	.00	.00	.00
Inservice Inspection						
Maintenance Personnel	0	0	0	.00	.00	.00
Operating Personnel	1	0	1	.11	.00	.10
Health Physics Personnel	0	0	0	.00	.00	.00
Supervisory Personnel	0	0	0	.00	.00	.00
Engineering Personnel	0	0	0	.00	.00	.00
Special Maintenance						
Maintenance Personnel	28	1	12	4.89	.22	1.39
Operating Personnel	1	0	0	.15	.00	.00
Health Physics Personnel	0	0	0	.00	.00	.00
Supervisory Personnel	3	0	0	.54	.00	.00
Engineering Personnel	1	0	0	.15	.00	.00
Waste Processing						
Maintenance Personnel	15	0	8	2.44	.00	1.39
Operating Personnel	0	0	0	.00	.00	.00
Health Physics Personnel	0	0	0	.00	.00	.00
Supervisory Personnel	1	0	0	.11	.00	.00
Engineering Personnel	0	0	0	.00	.00	.00
Refueling						
Maintenance Personnel	0	0	0	.00	.00	.00
Operating Personnel	0	0	0	.00	.00	.00
Health Physics Personnel	0	0	0	.00	.00	.00
Supervisory Personnel	0	0	0	.00	.00	.00
Engineering Personnel	0	0	0	.00	.00	.00
TOTAL						
Maintenance Personnel	47	1	20	7.73	.22	2.78
Operating Personnel	47	0	3	6.14	.00	.30
Health Physics Personnel	27	0	5	6.76	.00	.57
Supervisory Personnel	9	0	0	1.34	.00	.00
Engineering Personnel	5	0	0	.80	.00	.00
GRAND TOTAL	135	1	28	22.77	.22	3.65