

Indian Point 3  
Nuclear Power Plant  
P.O. Box 215  
Buchanan, New York 10511  
914 736.8001



**New York Power  
Authority**

John H. Garrity  
Resident Manager

June 4, 1993  
IPN-93-050

Docket No. 50-286  
License No. DPR-64

Thomas T. Martin  
Regional Administrator  
Region 1  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Dear Sir:

Licensee Event Report LER 93-018-00 is hereby submitted in accordance with the requirements of 10CFR50.73. This event is of the type defined in the requirements per 10CFR50.73 (a)(2)(ii)(B). The commitments made by the Authority are listed in Attachment 1.

Very truly yours,

A handwritten signature in cursive script that reads "John H. Garrity".

John H. Garrity  
Resident Manager  
Indian Point Three Nuclear Power Plant

JHG/fp  
Attachments

cc: Document Control Desk (Original)  
Mail Station PI-137  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

INPO Records Center  
700 Galleria Parkway  
Atlanta, Georgia 30339-5957

9306070345 930604  
PDR ADOCK 05000286  
S PDR

*JE 7/21*

Attachment 1  
LIST OF COMMITMENTS MADE IN LETTER IPN-93-

Number	Commitment	Due
IPN-93- -01	Personnel will be counselled on the importance of following plant procedures and maintaining control of the plant's design configuration.	06/09/93
IPN-93- -02	The hemyc blanket will be replaced as required per 10 CFR 50 Appendix R.	Prior to plant startup
IPN-93- -03	Performance and Reliability personnel will perform surveillance test 3PT-R102 to verify the presence and integrity of the fire protection barriers at all penetrations. Prior to being used, the test will be reviewed and if necessary revised to ensure it is adequate and complete to perform this task.	Prior to plant startup