

John H. Garrity Resident Manager

July 7, 1993 IPN-93- 079

U.S. Nuclear Regulatory Commission Document Control Desk Mail Station PI-137 Washington, D.C. 20555

Subject:

Indian Point 3 Nuclear Power Plant

Docket No. 50-286

Revised Reply To NRC IE Bulletin 80-05

Dear Sir:

The Authority is submitting this correspondence to revise our reply to the subject bulletin.

During a review of our Chemical and Volume Control System (CVCS) design and operation, an error was identified in our response to the subject bulletin. The referenced letter stated that the CVCS holding tanks were equipped with a vent and overflow to the external environment without means to isolate the vent path. Additionally, it stated that tanks were designed for an external pressure equal to atmosphere with vacuum in the tanks.

The correct information is that there is no vent or overflow to the external environment. The tanks vent to a header leading to the waste gas system. This header has a valve that is administratively controlled to be locked open.

In order to protect the CVCS holding tanks from a vacuum condition, the control circuit for each tank will be modified to trip gas stripper feed pumps and recirculation pumps and to provide a low pressure alarm. This modification will be completed prior to start up from the current outage.

Also attached is a list of commitments made in this letter by the Authority.

Very truly yours,

John H. Garrity Resident Manager

Indian Point Three Nuclear Power Plant

JHG/djc

cc: see next page

9307150053 930707 PDR ADDCK 05000286 [E1]

cc: Mr. Thomas T. Martin
Regional Administrator - Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

U. S. Nuclear Regulatory Commission Resident Inspector's Office Indian Point 3

Attachment IPN-93-079 List Of Commitments

Number	Commitment	Due
IPN-93-079	Implement a design modification to the chemical volume control system providing vacuum protection on the hold up tanks.	Prior to startup