Indian Point 3 Nuclear Power Plant P.O. Box 215 Buchanan, New York 10511 914 739.8200



New York Power Authority

January 4, 1991 IP3-91-003 IP3-91-001W

Docket No. 50-286 License No. DPR-64

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Mail Station PI-137 Washington, D.C. 20555

Dear Sir:

Enclosed you will find the monthly operating report relating to Indian Point 3 Nuclear Power Plant for the month of December 1990.

Vertruly ∦our ain

Joseph É. Russell Resident Manager Indian Point 3 Nuclear Power Plant

JER:SS:JB:sd:MOR.JB

Enclosure

÷

101230262

cc: Mr. Thomas T. Martin, Regional Administrator Region 1 U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

INPO Records Center Suite 1500 1100 Circle 75 Parkway Atlanta, Georgia 30339

PDR



OPERATING DATA REPORT

Docket No.	<u>50-286</u>
Date	01-04-91
Completed By	S. Smith
Telephone	914 736-8340
. •	

OPERATING STATUS

		•	Notes	
1.	Unit Name: Indian Point No. 3 Nuclear Po	ower Plant		
2.	Reporting Period: December 1990			
3.	Licensed Thermal Power (MWt): 3025			
4.	Nameplate Rating (Gross MWe): 1013		•	
5.	Design Electrical Rating (Net MWe):	965	· · ·	
6	Maximum Dependable Canacity (Gross MWe):	1000	· · · · ·	
7	Maximum Dependable Capacity (Net MWe):	965		
0	If Changes Occur in Canacity Patings (Ite	me Number	3 through 7) Since Last
0.	Poport Civo Poscong.		5 chi ough /	, binee habe
	Report: Give Reasons.			· · · · · · · · · · · · · · · · · · ·
a	Power Level to Which Restricted If Any ((Net MWe) ·		
10	Reasons for Restrictions If Any:	ince incy.		· ·
10.	Reasons for Rescrictions, if my.		•	
		No +	·····	
	μ.	his Month	Yr. to Date	Cumulative
11	Hours In Reporting Period	744	8,760	126.049
12	Number of Hours Reactor Was Critical	268.57	5,511,21	77,521,09
12.	Peactor Peserve Shutdown Hours	0	0	0
11	Hours Concrator On-Line	167 76	5 378	75 339 75
15.	Unit Deserve Shutdown Hours	0	· 0	0
16	Gross Thermal Energy Cenerated (MWH) 26	52 236	15 745 568	213 246 534
17	Gross Herman Energy Generated (MWH) (52,230	5 21/ 550	65 662 885
10	Net Electrical Concreted (MWH)	50 260	5 021 760	63 103 216
10.	Net Electrical Generated (MWH)	<u>20,200</u>	<u> </u>	50 0
19.	Unit Service Factor	22.5		59.8
20.	Unit Availability Factor		<u> </u>	52.41
21.	Unit Capacity Factor (Using MDC Net)	8.1		
22.	Unit capacity factor (Using DER Net)	<u> </u>		
23.	Unit Forced Outage Rate	<u> </u>		$\frac{10.1}{10.1}$
24.	Shutdowns Scheduled Over Next 6 Months (T)	/pe,Date,an	a Duration	of Each):
	* weighted Average		· · · · · · · · · · · · · · · · · · ·	
25	The chut Down Mt End Of Depart Device Ed	timated Dat	o of Startu	~·
25.	II Shut Down At End OI Report Period. Est	Imaleu Dat	e or scarcu	۷۰
26	Unita In Most Status (Drior to Commorgia)	Operation	·) •	
20.	Units in fest status (Filor to commercial		•	
		For	ogast	Achiovod
		FOI	ecasi	Achieveu
	THITMIN ODICIONI TON			
	INITIAL CRITICALITY			<u></u>
	INITIAL ELECTRICITY	· · · · ·	<u></u>	
	COMMERCIAL OPERATION		· · · · · · · · · · · · · · · · ·	
•		•		
		· · · ·	· · · ·	·

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	50-286
UNIT	· IP-3
DATE	01-02-91
COMPLETED BY	S. Smith
TELEPHONE	(914) 736-8340

MONI	HDECEMBER 1990		• •		
DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)		• .	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u> </u>		•	17	O
2	0	· ·		18	O
3	O ·	•	•	19	<u> </u>
4	0	•		20	<u> </u>
5	0			21	0
6	0			22	0
, 7	0			23	26
8	0			24	223
9	0	•		25	213
10	0			26	167
11	0		,	27	134
12	0			28	101
13				29	396
14 ·	0			30	519
15	O			31	647
16	0		÷		

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

Ħ

DOCKET NO. <u>50-286</u> UNIT NAME <u>INDIAN POINT NO</u>

3

DATE <u>01-04-91</u> COMPLETED BY <u>8. SMITH</u>

TELEPHONE (914) 736-8340

REPORT MONTH DECEMBER 1990

r======								······	
NO.	DATE	TYPE 1	DURATION (HOURS)	REASON 2	METHOD OF SHUTTING DOWN REACTOR 3	LICENSEE Event Report #	SYSTEM CODE 4	COMPONENT CODE 5	CAUSE & CORRECTIVE Action to prevent Recurrence
5	900915	s	547.98	с	1	NA	НА	TURBIN	THE UNIT WAS MANUALLY
									SECURED DURING A CONTROLLED SHUTDOWN FOR THE CYCLE 7/8 REFUELING OUTAGE.
6	901226	S	3.87	В	NA	NA	НА	TURBIN	TURBINE WAS MANUALLY SECURED TO PERFORM
									SURVEILLANCE TESTS 3PT-V6, <u>TURBINE</u> <u>GENERATOR MECHANICAL</u> <u>TRIP TEST</u> AND 3PT- V21, <u>TURBINE</u> <u>CENERATOR</u>
		<u>у</u>							<u>GENERATOR OVERSPEED</u> <u>TRIP TEST</u> .
7	901227	F	24.39	A	1	91-03-00	EB	TRANSF	BUS NO. 312 TRANS- FORMER FAULTED. ALL CIRCULATING WATER PUMPS TRIPPED. UNIT WAS MANUALLY TRIPPED.
8	901231	, F	38	A	NA	NA	xx	PUMPXX B	LOAD REDUCTION IN ORDER PERFORM REPAIRS ON NO. 31 HEATER DRAIN PUMP.
1 F: S:	234F: ForcedReason:MethodExhibit - InstructionsS: ScheduledA-Equipment1-Manualfor Preparation of DataB-Maintenance or Test2-Manual ScramEntry Sheets for LicenseeC-Refueling3-Automatic ScramEvent Report (LER) File (NUREG-D- Regulatory Restriction4-Other (Explain)0161)								

SUMMARY OF OPERATING EXPERIENCE

DECEMBER 1990

Indian Point Unit No. 3 was synchronized to the bus for a total of 167.76 hours producing a gross generation of 63,310 MWe.

Following the Cycle 7/8 Refueling Outage, the reactor was brought critical on December 20, at 0305 hours. The unit was synchronized to the bus on Decmeber 23, at 1959 hours, and proceeded to approximately 250 MWe for a Chemistry hold. On December 26, at 1100 hours, a load decrease was commenced in preparation for Surveillance Test's 3PT-V6, <u>Turbine Generator Mechanical Trip Test</u>, and 3PT-V21, <u>Turbine Generator Overspeed Trip Test</u>. The turbine was manually secured at 1248 hours to perform the tests. After the tests were completed the unit was synchronized to the bus at 1640 hours, and proceeded to approximately 250 MWe for a Chemistry hold.

On December 27, at 1111 hours, Control Room Operators received several category alarms and discovered that No.s 31-36 Circulating Water Pumps had tripped. The reactor and turbine were manually tripped and No. 32 Reactor Coolant Pump tripped on overcurrent. Plant conditions were stabilized. Investigation revealed that Bus No. 312 Transformer had faulted.

On December 28, at 0332 hours, the reactor was brought critical and the unit synchronized to the bus at 1134 hours, and proceeded to approximately 250 MWe for a chemistry hold. At 2015 hours, a load increase to 50% reactor power began, and was achieved at 0345 hours on December 29. A load increase to 80% reactor power then commenced.

On December 31, at 1000 hours, a load decrease commenced to 600 MWe in order to perform repairs on No. 31 Heater Drain Pump. The Unit reached 600 MWe at 1210 hours, and remained at 600 MWe for the remainder of the reporting period.